

Mary Allen

From: Mary Allen
Sent: Wednesday, October 10, 2018 5:06 PM
To: 'Ariel Herman'
Cc: Nathan Quarles; Alex Rosas; Darla Pimlott; Rosalind Girard; James Johnson
Subject: RE: 15190 Armstrong Woods Road septic - #SEP15-0329

Ari,

For clarification, the revised septic site plan is an "As Built" required from the contractor that installed the system.

Mary

Mary A. Allen
Environmental Health Specialist
Sonoma County, PRMD Permit Sonoma, Well & Septic
2550 Ventura Ave.
Santa Rosa, CA 95403
Office: (707) 565-1961
Cell: (707) 478-4169
Mary.Allen@sonoma-county.org

www.PermitSonoma.org

Permit Sonoma's Public Lobby is open Monday, Tuesday, Thursday and Friday from 8:00 AM until 4:00 PM, except Wednesdays, open from 10:30 AM to 4:00 PM.



From: Mary Allen
Sent: Wednesday, October 10, 2018 4:55 PM
To: 'Ariel Herman' <ariherman3@gmail.com>
Cc: Nathan Quarles <Nathan.Quarles@sonoma-county.org>; Alex Rosas <Alex.Rosas@sonoma-county.org>; Darla Pimlott <Darla.Pimlott@sonoma-county.org>; Rosalind Girard <Rosalind.Girard@sonoma-county.org>
Subject: RE: 15190 Armstrong Woods Road septic - #SEP15-0329

Hi, Ari,

To recap, we met at the Customer Service Cubicle last Wednesday, 10/03/2018, and I asked for several missing items to final the septic permit #SEP15-0073. On Tuesday, 10/09/2018, I received your email with the pump/pump basin specifications and a partial site plan. As I stated at the Cube, the building permit should not have been finalized until after the septic system permit was finalized.

Regarding your email submittals:

1. Thank you for the pump/pump basin specifications. I will check with staff to verify that this type of system is acceptable.
2. We still need the septic tank specifications.
3. I recently spoke with Rex Petersen about the incomplete 189, and now see that he gave final approval on 10/04/2018.
4. We need the septic site plan revised; the one you included in the email is a building site plan with the tank, pump basin and control panel added, but no piping, leachfield, etc. We need a complete parcel septic site plan showing the current configuration of all structures, septic piping from the house, tank, pump basin, piping to the leachfield, control panel, electrical lines to the panel, and the leachfield.

Thank you for your submittal,

Mary

Mary A. Allen

Environmental Health Specialist

Sonoma County, PRMD Permit Sonoma, Well & Septic

2550 Ventura Ave.

Santa Rosa, CA 95403

Office: (707) 565-1961

Cell: (707) 478-4169

Mary.Allen@sonoma-county.org

www.PermitSonoma.org

Permit Sonoma's Public Lobby is open Monday, Tuesday, Thursday and Friday from 8:00 AM until 4:00 PM, except Wednesdays, open from 10:30 AM to 4:00 PM.



From: Ariel Herman [<mailto:ariherman3@gmail.com>]

Sent: Tuesday, October 09, 2018 10:15 AM

To: Mary Allen <Mary.Allen@sonoma-county.org>

Subject: 15190 Armstrong Woods Road septic

Hi Mary Allen,

Please let me know if these documents are what is needed to pass our septic final. The pump tank and pump are a single unit, and the plan check photos show the delta 3 modification.

Best,

Ari Herman

THIS EMAIL ORIGINATED OUTSIDE OF THE SONOMA COUNTY EMAIL SYSTEM.

Warning: If you don't know this email sender or the email is unexpected,
do not click any web links, attachments, and **never** give out your user ID or password.