

**E**

Type

**X**

Plans

**SEP13-0021**

Permit Number

**30800**

Street Number

**SEAVIEW RD**

Street Name

**TIM**

Community Code

**109-480-025**

APN

This permit application must be signed on pertinent signature lines by the same person (i.e., contractor or owner/builder.) A letter of authorization from the owner must accompany this application if an agent is signing on the owner's behalf.

EXISTING USE(S) ON SITE: \_\_\_\_\_

SEP PERMIT # SEP13-0021

Building PERMIT # \_\_\_\_\_

OWNER'S NAME Timber Cove Fire Protection District

MAILING ADDRESS 30800 Seaview Road

CITY Cazadero STATE CA ZIP 95421

PHONE (\_\_\_\_) \_\_\_\_\_

INSTALLATION WILL SERVE:  EXISTING RESIDENCE  NEW RESIDENCE

REPLACEMENT RESIDENCE  SECOND UNIT  COMMERCIAL  REPAIR

OTHER: \_\_\_\_\_  ATTACHED CONDITIONAL STATEMENT

TOTAL (Existing + Proposed) 50 Total No. of Bedrooms: 50 GPD

Water Supply:  Public  Private

Lot Size: \_\_\_\_\_

**OWNER-BUILDER DECLARATION**

I hereby affirm under penalty of perjury that I am exempt from the Contractor's License Law for the following reason (Sec. 7031.5, Business and Professions Code): Any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractor's License Law (Chapter 9 (commencing with Section 7000) of Division 3 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500):

I, as owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale. (Sec. 7044 Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his or her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he or she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law.)

I am exempt under Sec. \_\_\_\_\_, B & P.C. for this reason: \_\_\_\_\_

**LICENSED CONTRACTOR'S DECLARATION**

I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with Section 7000) of Division 3 of the Business and Professions Code, and my license is in full force and effect.

Contractor \_\_\_\_\_ License Class \_\_\_\_\_

License Number \_\_\_\_\_ Expiration Date \_\_\_\_\_

**WORKER'S COMPENSATION DECLARATION**

I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation, as provided for by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued.

I have and will maintain worker's compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My worker's compensation insurance carrier and policy number are: \_\_\_\_\_

Carrier Policy No. \_\_\_\_\_

This section need not be completed if the permit is for one hundred dollars (\$100) or less. I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the worker's compensation laws of California, and agree that if I should become subject to the worker's compensation provisions of section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 1/17/13 Applicant Signature [Signature]

**A SEPTIC PERMIT SHALL EXPIRE IN THREE(3) YEARS FROM DATE OF ISSUANCE UNLESS OTHERWISE NOTED BY CODE ENFORCEMENT.**

THIS PERMIT IS LIMITED TO 180 DAYS.

Violation # NW399-0250

DATE 1/17/13

CODE ENFORCEMENT

**OWNER'S DECLARATION**

I agree above information is correct. I agree to comply with all local Ordinances and State (USE HEAVY LINES) construction. I hereby authorize representatives of the County of Sonoma to enter upon the above-mentioned property for inspection purposes. If, after making the Certificate of Exemption for the Worker's Compensation provisions of the Labor Code I should become subject to such provisions, I will forthwith comply. In the event of a violation of the Worker's Compensation law, this permit shall be deemed revoked.

DATE 1/17/13

Signature [Signature]

SIGNATURE OF APPLICANT

30800 Seaview Rd, Cazadero, CA 95421

Address

Construction and Permit Finaled by: [Signature] Date 2/24/17

ZIP

Contractor  Owner  Other Licensed Professional

County of Sonoma  
Permit & Resource Management Department  
Well & Septic Section  
2550 Ventura Avenue, Santa Rosa, CA 95403-2829  
(707) 565-1900

SEPTIC SYSTEM INSPECTION

Site Address: 30800 SEAVIEW Rd  
Owner: New Standard Sys  
SEP 13-0021

REQUEST FOR INSPECTION

Date of call: \_\_\_\_\_ Time: \_\_\_\_\_

Caller: \_\_\_\_\_

Caller's Phone No.: \_\_\_\_\_

Remarks: Need to final: As Built  
of final letter

Call taken by: \_\_\_\_\_

INSPECTION NOTICE

- Stop work immediately - Call Environmental Health Specialist  
Telephone \_\_\_\_\_ Hours \_\_\_\_\_
- OK to cover leachfield 20 tank,
- Provide Engineer's letter of approval
- Provide "As Built" plan to scale
- Call for inspection on pump & alarm
- Corrections needed - see remarks below
- OK to cover with Engineer's approval
- Issue Operational Permit

For further information call: \_\_\_\_\_

Hours & Day: \_\_\_\_\_

Remarks: 50' setback to bank, needs  
as built, 1 line at 72' <sup>new</sup> tank  
water tightness test, upsized  
pump 30 up to 40, Alarm  
good, passed squirt test,  
Greg probed depth - OK,  
OK'd pumped tank.  
M. W. C. C. 7/22/16

Environmental Health Specialist's Signature \_\_\_\_\_ Date \_\_\_\_\_

Received by: B. S. S.  
Contractor's Signature

Posted



**Adobe**  
**Associates, Inc.**  
 Civil Engineering,  
 Land Surveying &  
 Land Development  
 Services

August 12, 2016

Permit and Resource Management Department  
 Well and Septic Division  
 2550 Ventura Avenue  
 Santa Rosa, CA 95403

**RECEIVED**  
**AUG 24 2016**  
 PRMD - WELL & SEPTIC

Attn: Mary Allen

Site Address: 30800 Seaview Road  
 APN: 109-480-025  
 Permit No. SEP13-0021  
 Job No. 12205

The installation of the private wastewater disposal system designed by Adobe Associates, Inc. was inspected and found to be in substantial conformance with the enclosed as built plan. A successful water tightness test was performed on the existing septic tank and existing sump tank. The dose in the sump tank was set at 110 gallons and the dose counter was recorded at 15 on July 22, 2016. The installation is approved.

Sincerely,

Gregory Schram, PE 73540  
 My License expires 12-31-2016



**RECEIVED**  
**AUG 22 2016**  
 PERMIT AND RESOURCE  
 MANAGEMENT DEPARTMENT  
 COUNTY OF SONOMA

1220  
 North Dutton Ave.  
 Santa Rosa,  
 California  
 95401  
 707 541 2300  
 707 541 2301 - Fax  
 www.adobeinc.com