

BLD 18-5216

REESE CONSULTING
& ASSOCIATES GEOTECHNICAL
ENGINEERS

134 Lystra Court, Suite C
Santa Rosa, CA 95403
Tel: (707) 528-3078
Fax: (707) 528-2837
reese@sonic.net

Date: October 8, 2018
Job Name: Mason/Lewis Residence
Job No.: 1411.213-7
By: Jonathan D. Morris

On site at 4586 Lambert Dr. in Santa Rosa to observe footing excavations for the residence. The excavations are 18 to 24 inches deep and bottom on firm materials in conformance with our recommendations.

Our observation excludes: lines, grades, pier hole and/or footing, locations, number of holes, size of footings and reinforcement. This form does not constitute authority for placing concrete; such authorization must be obtained from the Building Official.

REESE & ASSOCIATES

Signed Jonathan D. Morris G2911