



DECEMBER 21, 2018

SPECIAL INSPECTION REPORT #1

CSE FILE #: 18-12

BLD18-1958

PROJECT NAME: LOWENTHAL RESIDENCE

ADDRESS: 93 OXFORD COURT, SANTA ROSA, CA 95403

TYPE OF REVIEW: SPECIAL INSPECTION FOR EPOXY ANCHORS

EPOXY ESR-REPORT NUMBER: SIMPSON SET-XP ESR-2508

REPORT DATE: 10-2-18

DATE OF VISIT: 10-2-18

TIME: 3:15PM

WEATHER: CLOUDY

CONTRACTOR:

STATUS OF CONSTRUCTION:

PRESENT AT SITE DURING INSPECTION: CHRISTIAN (CSE)

SPECIAL INSPECTION PER 2016 CBC SECTIONS 1702 AND 1705 WAS PERFORMED BY CREATIVE STRUCTURAL ENGINEERING FOR THE SPECIFIED EPOXY ANCHORS. ALL ITEMS REVIEWED WERE FOUND TO BE IN GENERAL CONFORMANCE WITH THE APPROVED CONSTRUCTION DOCUMENTS AND REVISIONS AS NOTED BELOW:

1. ALL HOLES WERE DRILLED TO THE PROPER DEPTH AND DIAMETER AS SPECIFIED IN THE ESR REPORT.
2. ANCHOR TYPE AND DIAMETER WAS VERIFIED.
3. ADHESIVE TYPE AND EXPIRATION DATE WAS VERIFIED AS ACCEPTABLE.
4. ANCHORS REVIEWED WERE INSTALLED INTO THE DRILLED HOLES PER THE ESR-REPORT REQUIREMENTS.

ADDITIONAL REMARKS IF APPLICABLE:

NO EXCEPTIONS NOTED.