

B

Type

Plans

B- 129914

Permit Number

5258

Street Number

Dry Creek Rd

Street Name

Gey

Community Code

090-220-016

APN

SONOMA COUNTY PERMIT AND RESOURCE MANAGEMENT Building and Land Division
 575 Administration Drive, Room 114 A, Santa Rosa, CA 95403-2884 Tel. (707) 527-2221 Fax (707) 527-3767
 REQUESTS FOR INSPECTION — AT LEAST 24 HOURS IN ADVANCE (707) 527-3551

JOB ADDRESS: 5258 DRY CREEK
 NEAREST CROSS STREET: DITCHER DR
 MAP REFERENCE: []
 PERMIT NUMBER: 129914
 INSPECTION AREA: 1

OWNER
 NAME: LEN WELLS
 MAILING ADDRESS: 5258 DRY CREEK TEL. NO. _____
 CITY: HOLYWOOD ZIP CODE _____

PROJECT
 ADDRESS: 5258 DRY CREEK
 CITY: HOLYWOOD
 SUBDIVISION NAME: _____ UNIT NO. _____ LOT _____ BLOCK _____
 ASSESSOR'S PARCEL NO: 090-220-021608
 NEAREST CROSS STREET: _____

CONTRACTOR
 NAME: RICH RYAN CONSTR.
 ADDRESS: P.O. Box 1717 TEL. NO. 423-7324
 CITY: HEALYBURG ZIP CODE 95448
 STATE: _____ LIC CLASS: B
 LIC NO: 305863

DESIGNER
 NAME: DOUGLAS ARCHITECT
 ADDRESS: 666 BRIDGEWAY TEL. NO. 433-2029
 CITY: SAN RAFAEL ZIP CODE 94965

1 LICENSED CONTRACTORS DECLARATION: I hereby affirm that I am licensed under provisions of Chapter 9 (commencing with Section 7000) of Division 3 of the Business and Professions Code, and my license is in full force and effect.
 Contractors Signature: [Signature] Lic. # 305863

2 OWNER-BUILDER DECLARATION: I hereby affirm that I am exempt from the Contractor's License Law for the following reason (Sec. 7031.5 Business and Professions Code: Any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure prior to its issuance, also requires the applicant for such permit to file a signed statement that he is licensed pursuant to the Contractor's License Law (Chapter 9 (commencing with Section 7000) of Division 3 of the Business and Professions Code) or that he is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by an applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500).
 I, as owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professions Code: The Contractor's License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or through his own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he did not build or improve for the purpose of sale.)
 I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractor's License Law does not apply to an owner of property who builds or improves thereon, and contracts for such projects with a contractor(s) licensed pursuant to the Contractor's License Law.)
 I am exempt under Sec _____, B & P.C. for this reason: _____
 Owners Signature: _____

3 WORKER'S COMPENSATION DECLARATION: I hereby affirm that I have a certificate of consent to self-insure, or a certificate of Worker's Compensation Insurance, or a certified copy thereof filed with the Permit and Resource Management Department (Sec. 3300 Lab. C.)
 Policy # ON FILE
 Applicant's Signature: [Signature] Exp. Date 10-1-95

4 CERTIFICATE OF EXEMPTION FROM WORKER'S COMPENSATION INSURANCE: I hereby certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the Worker's Compensation Laws of California.
 Owner's or Contractor's Signature: _____

5 CONSTRUCTION LENDING AGENCY: I hereby affirm that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C.)
 Lender's Name: _____
 Lender's Address: _____

PERMITTEE
 THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK AUTHORIZED IS NOT COMMENCED WITHIN 180 DAYS, AND IS SUBJECT TO EXPIRATION IF WORK THEREUNDER IS SUSPENDED FOR 180 DAYS.
 NAME: [Signature]
 ADDRESS: 666 BRIDGEWAY SAN RAFAEL
 I certify that I have read this application and state that the above information is correct, and that I am the owner or the duly authorized agent of the owner. I agree to comply with all County and State laws relating to building construction. I hereby authorize representatives of the County of Sonoma to enter upon the above-mentioned property for inspection purposes. If, after making the Certificate of Exemption from the Worker's Compensation provisions of the Labor Code, I should become subject to such provisions, I will forthwith comply. In the event that I do not comply with the Worker's Compensation law, this permit shall be deemed revoked.
 Signature: [Signature] Date: 4/13/95
 Contractor Agent for Contractor Agent for Owner

PLANNING DIVISION
 ZONING: LR20-20Z FILE # UP-90093 ACRES 3.17
 EXISTING USE/STRUCTURES: S.F.D. w/ CARPORT
 PROPOSED USE/STRUCTURES: 108 square foot Addition to existing 600 S.F. GUEST cottage
 (Changes/Additions)
 MINIMUM YARD REQUIREMENTS: Front 30' Left 10' Right 10' Rear 20'
 FIRE SETBACK OF 30' FROM ALL PROPERTY LINES REQUIRED YES NO
 APPROVAL FOR PERMIT ISSUANCE: Date _____
 APPROVAL FOR OCCUPANCY: Date 4-13-95 [Signature]
 HOLD FINAL FOR _____ OTHER REMARKS _____
AS per Richard Lehtinen
 DEVELOPMENT FEES: REQUIRED EXEMPT SOUND MITIGATION: REQUIRED EXEMPT

CONDITION OF SOIL AT JOB SITE:
 ORIGINAL ENGINEERED FILL LOOSE FILL
 SITE REVIEW: 0-5%

by: SA Date: 4/17/95
REQUIRED REPORTS: GEOLOGY SOILS COMPACTION
 FLOOD ZONE: YES NO 100 YR FLOOD ELEV. _____
 NSCAPCD: YES NO PRE-FIRM _____ %

SEWER CONNECTION:
 AVAILABLE APPROVED BY _____
 FEES PAID DATE _____

ROAD ENCROACHMENT:
 NO PERMIT REQ APPROVED BY [Signature]
 FEES PAID DATE _____

SEPTIC TANK INSTALLATION: (Health Dept.)
 Permit/Clearance # 95-6611 LU
 Date Rec'd 6-1-95 Date Issued 5-30-95

WORK AUTHORIZED:
addition to existing guest cottage

	SIZE IN SQUARE FEET	RATE PER SQUARE FOOT	VALUE
FLOOR AREA	<u>108</u>	<u>74-</u>	<u>7,992</u>
GARAGE CARPORT			
DECK AWNING			
TOTAL FEES - Par Chap 7, et seq. Sonoma County Code		TOTAL	<u>7,992</u>
<input checked="" type="checkbox"/> BUILDING			<u>91.85</u>
<input type="checkbox"/> PLAN CHECK	<u>31990</u>		
<input checked="" type="checkbox"/> PLUMBING			<u>26-</u>
<input checked="" type="checkbox"/> ELECTRICAL			<u>26</u>
<input type="checkbox"/> MECHANICAL			
<input type="checkbox"/> GRADING			
<input type="checkbox"/> SITE/PROP			
<input checked="" type="checkbox"/> PLANNING			<u>16.-</u>
<input type="checkbox"/> FIRE			
<input checked="" type="checkbox"/> SEISMIC			<u>.80</u>
<input checked="" type="checkbox"/> PROCESSING FEE			<u>17</u>
<input type="checkbox"/> INVEST. FEES			
<input type="checkbox"/> ORD #4618 FEES			
		TOTAL \$	<u>177.65</u>
<input checked="" type="checkbox"/> PLANS APPROVED		<input type="checkbox"/> NO PLANS SUBJECT TO FIELD INSPECTION	
APPROVED BY: <u>[Signature]</u>		DATE: <u>4/30/95</u>	
DATE RECEIVED BY: <u>4-13-95</u>		PREVIOUS PERMIT NO: <u>019756</u>	DATE CLEARED BY: <u>6-1-95</u>
TYPE OF CONSTRUCTION: <u>UR R3</u>		MACHINE SPACE FOR PERMIT FEE:	
OCCUPANCY: <u>R3</u>		BLDG.	\$91.85
NO OF STORIES: <u>1</u>	NO OF BEDROOMS: <u>1</u>	BLDG.	\$26.00
CERTIFICATE OF OCC		BLDG.	\$26.00
FINAL DATE		PLANIG	\$16.00
INSPECTOR		EQ PGM	\$0.80
		BLDG.	\$17.00
		***TTL	\$177.65
		CHECK	\$177.65
		CHNG	\$0.00

SPECIAL INSPECTION REQUIRED?

YES

NO

IF YES, SEE ADDITIONAL SHEET

INSPECTION RECORD	DATE	NAME	REMARKS
FOUNDATION			
FORMS/SETBACK			
FOOTING			
WALLS			
UNDER GROUND #			
CAISSONS/PIERS			
SLAB			
MASONRY			
RETAINING WALLS			
FIREPLACE			
FOOTING			
HEARTH/PROTECTION			
THROAT			
CHIMNEY			
UNDERFLOOR/SLAB			
U/F ELECTRICAL			
U/F MECHANICAL			
U/F PLUMBING			
U/F FRAMING			
U/F INSULATION			
DIAPHRAGMS			
SHEAR WALLS			
<input type="checkbox"/> INTERIOR			
<input type="checkbox"/> EXTERIOR			
ROOF DIAPHRAGM			
FLOOR DIAPHRAGM			
SIDING/SHEATHING			
HOLD DOWNS			
STUCCO/PLASTER/LATH			
CLOSE-IN			
ROUGH ELECTRICAL			
ROUGH MECHANICAL			
ROUGH PLUMBING			
ROUGH FRAME			
SMOKE DETECTORS			
INSULATION			
WALLBOARD			
STUCCO/PLASTER/SCRATCH			
TUB/SHOWER PAN			
SUSPENDED CEILING			
ROUGH ELECTRICAL			
ROUGH MECHANICAL			
EXISTING			
STAIRS/HANDRAILS			
RAMPS			
CORRIDORS/DOORS			
HANDICAP REQ.			
ENERGY REQ.			
TEMP OCCUPANCY			
TEMP. ELECTRIC			
TEMP. GAS			
ELEC. METER AUTH.			
PANEL BOARDS/SERVICE			
GAS METER AUTH.			
GAS PRESSURE TEST			
HOUSE			
YARD			
MANUF. HOME FOUNDATION			
MANUF. HOME INSTALLATION			FIRE INSP. REQ'D <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
CONTINUITY			Inspected by:
STAIRS/SKIRTS			
RIDGE BOLTING			
SWIMMING POOL			
PRE-GUNITE			
PRE-DECK			
PRE-PLASTER/FENCE			CLEARANCES:
GRADING FINAL			FIRE
ELECTRICAL FINAL			HEALTH DEPT.
MECHANICAL FINAL			PLANNING
PLUMBING FINAL			SANITATION
FINAL			N.C.A.P.C.D.
OCCUPANCY (OK TO OCCUPY)			
			PLAN RETENTION REQUIRED
			Yes <input type="checkbox"/> No <input type="checkbox"/>

10/30/95 P02
10/30/95 DL

PERMIT # 129914

SPECIAL INSPECTION REQUIREMENTS

Project Title REMODEL ADDITION Project Address 5258 DRY CREEK RD
Owner FWDW Address WASH

The following tests and inspections as indicated below; will be required as detailed in applicable project plans, specifications and the Uniform Building Code. These inspections are in addition to inspections performed by the Building Inspection Department.

Individuals performing these duties must be qualified, and approved by the Building Department prior to performing inspections. Individuals certified in a special inspection category by a qualified independent third party organization, and individuals employed by a recognized testing laboratory and under the direct supervision of a Civil Engineer are considered qualified and approved.

Special Inspection Reports shall be submitted to the Building Inspection Department, engineer or architect of record and other designated individuals. Reporting methods shall be as described in plans, specifications and the Building Code. A final inspection report will be required prior to occupancy of the building.

SPECIAL INSPECTIONS

Grading, Excavation and Fills:
During fill placement, including subbase preparation, fill material and placement and compaction verification. During construction of buttress fills. During engineered grading procedures.

Piling, Drilled Piers, Caissons:
During driving and testing of piles and construction of cast-in-place drilled piers or caissons.

Reinforcing Steel:
During placement of all reinforcing steel, or inspection of all reinforcing prior to closing of forms and prior to concrete delivery. Excluding _____

Prestressed Steel:
During placing of all tendons and prestressing steel, or inspection of all tendons and prestressing steel prior to closing of forms and prior to concrete delivery. Also during all stressing and grouting operations.

Concrete:
During the taking of test specimens and placing of all reinforced concrete and pneumatically placed concrete. Excluding _____

Concrete Frames, Ductile Moment-Resisting:
A specially qualified inspector, under the supervision of the person responsible for the structural design, shall provide continuous inspection of the placement of the reinforcing and concrete.

MASONRY:
During placing of all masonry units, placement of reinforcement, inspection of grout space, immediately prior to closing of clean-outs, and during all grouting operations. Excluding _____

Welding:
During all structural welding, including welding of reinforcing steel and shop welding. Excluding _____

Welding of Ductile Moment-Resisting Steel Frames:
See plans and specifications for special requirements.

High Strength Bolting:
During all bolt installation and tightening operations, or provide preconnection inspections combined with tension verifications for 10% of the bolts in each connection with a minimum of 2 bolts per connection. Excluding _____

Gypsum Concrete, Reinforced:
During mixing and placing of Class B gypsum concrete.

Insulating Concrete Fill:
During application of insulating concrete fill when part of a structural system.

Spray Applied Fire Proofing:
During mixing and applying of all spray applied fire resistive material including inspection of surfaces to be covered prior to application.

X EXPOXY SYSTEM - HDS

Requirements Determined PER ARCH
Architect/Engineer

Requirements Approved _____
Building Department

Date 5-30-95

Original: Building Department Pink: Owner
Yellow: Architect/Engineer Buff: Contractor/Permittee

**BUILDING PERMIT CHECK LIST
SONOMA COUNTY BUILDING INSPECTION**

NAME: Wells **PLANCHECK #** 31988

If corrections are needed, check which return procedure is preferred:

Pickup
Phone 415-332-0298

Mail to _____ Mailing Address(_____)

You have submitted plans to this department for review. Clearances designated will be required prior to issuance of your building permit. You are advised to contact these agencies early in your process to prevent unnecessary delays in building permit issuance.

<u>AGENCY OR CLEARANCE REQUIRED</u>	<u>CLEARANCES</u>	
	<u>REQUIRED</u>	<u>RECEIVED</u>
<u>PLANNING</u>	Ch	[]
<u>BUILDING DEPARTMENT:</u>		
GRADING PERMIT	[]	[]
GEO TECHNICAL REPORT	[]	[]
ELEVATION CERTIFICATE (FLOOD)	[]	[]
ADDITIONAL FEES (PLANCHECK) (VIOLATION)	[]	[]
OWNER BUILDER VERIFICATION	[]	[]
WORKER'S COMPENSATION	Ch	SB
SCHOOL MITIGATION FEE	Ch	SB
DEVELOPMENT FEES	N.A.	[]
ASSESSOR'S FLOOR PLAN (TO SCALE)	11X17 or smaller Ch	[]
<u>HEALTH DEPARTMENT:</u>		
SEPTIC	Ch	SB
FOOD HANDLING	[]	[]
<u>PUBLIC WORKS:</u>		
SEWER	[]	[]
ROAD ENCROACHMENT	Ch	SB
PARCEL MAP IMPROVEMENT CONDITIONS	[]	[]
<u>SPECIAL DISTRICTS (LIST DISTRICT):</u>		
WATER _____	[]	[]
SEWER _____	[]	[]
<u>UTILITY CERTIFICATE:</u>		
SANTA ROSA	[]	[]
<u>SONOMA COUNTY WATER AGENCY:</u>		
DRAINAGE	[]	[]
CREEK SETBACK	[]	[]
<u>FIRE MARSHALL</u> _____	Ch	N.A.
<u>AIR QUALITY CONTROL (ASBESTOS DECLARATION AB2791)</u>	[]	[]

NOTE: The PINK COPY is a preliminary determination of required clearances. A complete list will be developed during the plan review process.

SPECIAL INSPECTION REQUIREMENTS

Project Title REMODEL ADDITIONAL Project Address 5258 DRY CREEK RD
Owner FWDW Address UJH

The following tests and inspections as indicated below, will be required as detailed in applicable project plans, specifications and the Uniform Building Code. These inspections are in addition to inspections performed by the Building Inspection Department.

Individuals performing these duties must be qualified, and approved by the Building Department prior to performing inspections. Individuals certified in a special inspection category by a qualified independent third party organization, and individuals employed by a recognized testing laboratory and under the direct supervision of a Civil Engineer are considered qualified and approved.

Special Inspection Reports shall be submitted to the Building Inspection Department, engineer or architect of record and other designated individuals. Reporting methods shall be as described in plans, specifications and the Building Code. A final inspection report will be required prior to occupancy of the building.

SPECIAL INSPECTIONS

- Grading, Excavation and Fills:
During fill placement, including subbase preparation, fill material and placement and compaction verification. During construction of buttress fills. During engineered grading procedures.
- Piling, Drilled Piers, Caissons:
During driving and testing of piles and construction of cast-in-place drilled piers or caissons.
- Reinforcing Steel:
During placement of all reinforcing steel, or inspection of all reinforcing prior to closing of forms and prior to concrete delivery.
Excluding _____
- Prestressed Steel:
During placing of all tendons and prestressing steel, or inspection of all tendons and prestressing steel prior to closing of forms and prior to concrete delivery. Also during all stressing and grouting operations.
- Concrete:
During the taking of test specimens and placing of all reinforced concrete and pneumatically placed concrete.
Excluding _____
- Concrete Frames, Ductile Moment-Resisting:
A specially qualified inspector, under the supervision of the person responsible for the structural design, shall provide continuous inspection of the placement of the reinforcing and concrete.
- MASONRY:
During placing of all masonry units, placement of reinforcement, inspection of grout space, immediately prior to closing of clean-outs, and during all grouting operations.
Excluding _____
- Welding:
During all structural welding, including welding of reinforcing steel and shop welding.
Excluding _____
- Welding of Ductile Moment-Resisting Steel Frames:
See plans and specifications for special requirements.
- High Strength Bolting:
During all bolt installation and tightening operations, or provide preconnection inspections combined with tension verifications for 10% of the bolts in each connection with a minimum of 2 bolts per connection.
Excluding _____
- Gypsum Concrete, Reinforced:
During mixing and placing of Class B gypsum concrete.
- Insulating Concrete Fill:
During application of insulating concrete fill when part of a structural system.
- Spray Applied Fire Proofing:
During mixing and applying of all spray applied fire resistive material including inspection of surfaces to be covered prior to application.

X EXPOXY SYSTEM - HDS

Requirements Determined PER ARCH
Architect/Engineer

Requirements Approved [Signature]
Building Department

Date 5-30-95

Original: Building Department Pink: Owner
Yellow: Architect/Engineer Buff: Contractor/Permittee

COUNTY OF SONOMA
 PUBLIC HEALTH DEPARTMENT
 1030 CENTER DR. - SUITE A - SANTA ROSA, CA 95403-2087 - PHONE (707) 525-6500

APPLICATION FOR PRIVATE SEWAGE DISPOSAL PERMIT

APPLICATION FOR PUBLIC HEALTH CLEARANCE FOR:

Application is hereby made to the Sonoma County Health Officer for a permit to construct or repair a sewage disposal system as described below in compliance with the code of Sonoma County or for clearance for other construction.

APPLICANT: PLEASE PRESS HARD (USE BLACK INK). FILL IN BETWEEN HEAVY LINES ONLY AND SEE REVERSE SIDE FOR INSTRUCTIONS.

JOB ADDRESS: 525B DRY CREEK RD.
 NEAREST CROSS STREET: DUNCAN CREEK RD.
 ASSESSOR'S PARCEL NO.: 09A-220-06.27.08
 SUBDIVISION: HEADSIBAL LOT: _____ BLK.: _____
 CITY: HEADSIBAL STATE: CA ZIP: 95448

OWNER'S NAME: KEN WELLS
 MAILING ADDRESS: 54 ATWOOD AVE
 CITY: SALISALVO STATE: CA ZIP: 94945 PHONE NUMBER: 433-5303

SEWAGE DISPOSAL SYSTEM CONTRACTOR: _____ TEL. NO.: _____
 ADDRESS: _____
 GENERAL CONTRACTOR: RICH RYAN CONSTRUCTION

INSTALLATION WILL SERVE:
 RESIDENCE APARTMENT HOUSE COMMERCIAL MOBILE HOME
 MOTEL OTHER BUILDING CONST. NEW ADDN/ALTER

TERMS OF PERMIT
 APPLICANT AGREES THAT:
 1. HEALTH DEPARTMENT ENVIRONMENTAL HEALTH SPECIALIST WILL BE NOTIFIED A MINIMUM OF 24 HOURS PRIOR TO COMMENCING WORK.
 2. HEALTH DEPARTMENT ENVIRONMENTAL HEALTH SPECIALIST AND ENGINEER'S OR CONSULTING ENVIRONMENTAL HEALTH SPECIALIST'S INSPECTION, WHEN INDICATED, WILL BE OBTAINED PRIOR TO COVERING THE SYSTEM.
 3. THE JOB CARD AND A COPY OF THE APPROVED SEWAGE DISPOSAL SYSTEM DESIGN SHALL BE AVAILABLE AT THE JOB SITE AT ALL TIMES.
 4. ANY DEVIATION FROM APPROVED PLAN WITHOUT PRIOR APPROVAL OF THE HEALTH OFFICER WILL BE CAUSE FOR STOPPING WORK UNTIL THE CHANGES ARE FULLY JUSTIFIED AND APPROVED.
 5. THE SEPTIC TANK MUST BE I.A.P.M.O. APPROVED.
 6. PRIOR TO AUTHORIZING OCCUPANCY OF ANY BUILDING WITH AN ENGINEER OR CONSULTING ENVIRONMENTAL HEALTH SPECIALIST DESIGNED SYSTEM, A SIGNED STATEMENT BY THE DESIGNER CERTIFYING THAT THE SYSTEM WAS INSTALLED IN COMPLIANCE WITH THE APPROVED PLAN MUST BE SUBMITTED TO THE PUBLIC HEALTH OFFICER.
 7. THIS PERMIT IS SUBJECT TO REVOCATION IF FOUND TO BE IN NONCONFORMANCE WITH SONOMA COUNTY CODE OR STANDARDS OF THE PUBLIC HEALTH DEPARTMENT.
 8. THIS PERMIT IS NOT TRANSFERABLE.

IT IS UNDERSTOOD THAT THE ISSUANCE OF A PERMIT IN NO WAY INDICATES THAT A GUARANTEE OF PERFECT AND INDEFINITE OPERATION OF THIS SYSTEM IS MADE BY THE COUNTY OF SONOMA PUBLIC HEALTH DEPARTMENT AND THAT THE OWNER IS REQUIRED TO MAKE ANY REPAIRS NECESSARY TO CONFINE SEWAGE BELOW THE SURFACE OF THE GROUND. APPROVAL IS BASED UPON INFORMATION SUBMITTED BY THE APPLICANT. FIELD CONDITIONS AT VARIANCE WITH APPLICATION MAY VOID PERMIT.
 I HEREBY ACKNOWLEDGE THAT I HAVE READ THIS APPLICATION AND THE INSTRUCTIONS ON THE REVERSE SIDE AND STATE THAT THE ABOVE IS CORRECT AND AGREE TO COMPLY WITH ALL COUNTY ORDINANCES AND STATE LAWS REGULATING CONSTRUCTION OF PRIVATE SEWAGE DISPOSAL SYSTEMS. THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK AUTHORIZED IS NOT COMMENCED WITHIN 180 DAYS.

CONTRACTOR'S LICENSE LAW CERTIFICATE
 (COMPLETE EITHER A OR B)
 A. THE APPLICANT IS LICENSED UNDER THE PROVISIONS OF THE CONTRACTOR'S LICENSE LAW UNDER SONOMA COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH WHICH LICENSE IS RECALIBRATED EFFECTIVE DATE: _____
 B. THE APPLICANT IS EXEMPT FROM THE CONTRACTORS LICENSE LAW FOR THE FOLLOWING REASONS:
 1) OWNER/BUILDER
 2) OTHER (EXPLAIN)

APPLICANT: _____ DATE: _____
 APPLICANT: _____ DATE: _____
 APPLICANT: _____ DATE: _____

CONSTRUCTION APPROVED BY: _____ DATE: 5/20/95
 SITE ID NUMBER: _____

WORKMEN'S COMPENSATION CERTIFICATE
 (One or Two must be completed)
 1. A currently effective certificate of Workmen's Compensation Insurance coverage is on file with the Sonoma County Public Health Department.
 2. I certify that in the performance of the work for which this permit is issued I shall not employ any person in any manner so as to become subject to the workmen's compensation laws of California.
 Compensation Insurance Policy #: _____
 is currently in force. 05/04/95

SEP TAX 499.00
 TITL TAX 499.00
 CHECKS 499.00
 CHANGE 70.68 #2 7:00

SONOMA COUNTY BUILDING INSPECTION DEPARTMENT

PERMIT QUESTIONNAIRE

Prior to issuance of a building permit, this department is required to verify that your project is consistent with regulations of other agencies. This questionnaire will assist us in informing you of those agencies you must contact and those approvals you must secure prior to issuance of a building permit.

PROJECT ADDRESS: 5258 Dog Creek

Sewage disposal for the subject building will be provided by:
Connection to public sewer: _____
Septic Disposal System: X
The proposed building contains no plumbing: _____

Water for the subject building will be provided by:
A private well: X
From the following water district: _____
The building contains no plumbing or water systems: _____

The subject building is located in the following School District:
HEALDSBURG

The subject building (___is), (Xis not), (___may be) located within the Santa Rosa sphere of influence. These are the areas of anticipated future City annexations. Projects within these areas are subject to City review and approval prior to building permit issuance.

Access to the property:
Exists and will not be altered: X
Will be developed or altered: _____
Access is from a public or private street: _____

Fire protection at this property is provided by the following Fire District: GEYSERVILLE. This property (Xis), (___is not) in a State Wildfire Responsibility Area.

Is project in Northern Sonoma County Air Pollution Control District (check map) YES X NO _____

Will the building occupants need to comply with the applicable requirements of Sections 25505, 25533 and 25534 of the Health and Safety Code and the requirements for a permit for construction or modification from the Air Quality Control District? YES ___ NO X

Written asbestos notification pursuant to Part 61 of Title 40 of the Code of Federal Regulations is required when asbestos exists in buildings, or portions thereof, undergoing demolition. I hereby declare that demolition authorized by this permit is for construction that (___does), (Xdoes not) contain asbestos or, that no demolition is authorized by this permit.

Applicant: [Signature] Date: 1/26/95

Received By: [Signature]