

B

Type



Plans

BLD 14-2815

Permit Number

4401

Street Number

Slusser Rd

Street Name

SR0

Community Code

057-070-031

APN

COUNTY OF SONOMA - PERMIT AND RESOURCE MANAGEMENT DEPARTMENT

2550 Ventura Avenue, Santa Rosa, CA 95403 (707) 565-1900 FAX (707) 565-1103

Please Print
 Your Name: Tiana Fillman Date Applied: 06/23/14

INFORMATION WITHIN HEAVY LINE TO BE COMPLETED BY APPLICANT

SITE LOCATION INFORMATION - PRINT CLEARLY

Site Address: 4401 Slusser Rd. City: Windsor ZIP: 95492
 Cross-Street: _____ APN: 05707003 Project Phone #: 707-963-1466 Project Fax #: 707-963-5027
 Directions: Sonoma Cutrer Vineyards Email address: bill@valleyarchitects.com Lot # _____
 Describe Project: Conference & Office Addition / Tasting Room Remodel Living Area: N/A Contract Price: _____
 Garage: N/A Decks: _____

OWNER NAME AND ADDRESS
 Name: Sonoma Cutrer Vineyards
 Mailing Address: 4401 Slusser Rd. P.O. Box 9
 City: Windsor-Fulton State: CA ZIP: 95492
 Day Ph: () Fax: () 95439

APPLICANT NAME AND ADDRESS
 Name: Tiana Fillman
 Mailing Address: 1560 Railroad Ave.
 City: St. Helena State: CA ZIP: 94574
 Day Ph: (707-963-1466) Fax: (707-963-5027)

CONTRACTOR INFORMATION
 Company Name: _____
 Address: _____
 City: _____ State: _____ ZIP: _____
 Day Ph: () Fax: ()

OTHER PERSONS (ARCHITECT, ENGINEER, ETC.)
 Name: Bill Bylund Jeff
 Address: 1560 Railroad Ave.
 City: St. Helena State: CA ZIP: 94574
 Day Ph: (707-963-1466) Fax: (707-963-5027)
 License No: C13213 Exp. Date: 9-30-15

WORKER'S COMPENSATION DECLARATION
 I hereby affirm under penalty of perjury one of the following declarations:
 I have and will maintain a certificate of consent to self-insure for worker's compensation, as provided for by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued.
 I have and will maintain worker's compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My worker's compensation insurance carrier and policy number are:

CONSTRUCTION LENDING DECLARATION
 I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued. (Sec. 3097, Civ. C.)
 Lenders Name: _____
 Lenders Address: _____

Carrier Policy No. _____
 (This section need not be completed if the permit is for one hundred dollars (\$100) or less.)
 I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the worker's compensation laws of California, and agree that if I should become subject to the worker's compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.
 Exp. Date: _____ Applicant: _____

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL, AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000), IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST, AND ATTORNEY'S FEES.

FOR DEPARTMENT USE

Zoning: UPE 07-0013 File No: UPE 07-0013 Acres: 4.00
 Existing Use/Structures: Winery
 Proposed Use/Structures: Expansion into tasting & offices
 Zoning Min. Yard Requirements: Front _____ Left _____ Right _____ Back _____
 NOTE: Fire Safe Standards require all parcels greater than 1 Acre to have a min. 30' setback unless mitigated. Mitigation Required Address subject to change
 Approval for Permit Issuance: _____ Approval for Occupancy: _____
 By: _____ Date: 7/8/14

OWNER-BUILDER DECLARATION
 I hereby affirm under penalty of perjury that I am exempt from the Contractor's License Law for the following reason (Sec. 7031.5, Business and Professions Code: Any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractor's License Law (Chapter 9 (commencing with Section 7000) of Division 3 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500).):
 I, as owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044 Business and Professions Code: The Contractor's License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his or her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he or she did not build or improve for the purpose of sale.)
 I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractor's License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractor's License Law.)
 I am exempt under Sec. _____, B & P.C. for this reason _____

By my signature below I acknowledge that, except for my personal residence in which I must have resided for at least one year prior to completion of the improvements covered by this permit, I cannot legally sell a structure that I have built as an owner-builder if it has not been constructed in its entirety by licensed contractors. I understand that a copy of the applicable law, Section 7044 of the Business and Professions Code, is available upon request when this application is submitted or at the following website: <http://www.leginfo.ca.gov/calaw.html>.
06/23/14 [Signature]
 Date Signature of Property Owner or Authorized Agent

Sewer Connection: Available Fees Paid
 Approved by: _____ Date: _____

Road Encroachment: Fees Paid
 Approved by: _____ Date: _____

Septic System Permit/Clearance #
 Approved by: [Signature] Date: 9-4-14

Flood Zone: Yes No 100 Year Flood Elevation: _____
Site Review Structure within floodway
Drainage Review [Signature] Date: 6/23/14

Fire: S. Mosiuschak Date: 9-2-14

Code Enforcement Violation Yes No Violation # _____
 This permit is limited to _____ days.

LICENSED CONTRACTOR'S DECLARATION
 I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with Section 7000) of Division 3 of the Business and Professions Code, and my license is in full force and effect.
 Lic. Class _____ Lic. No. _____
 Exp. Date _____ Contractor _____

ASBESTOS DECLARATION
 Written asbestos notification pursuant to Part 61 of Title 40 of the Code of Federal Regulations is required when asbestos exists in buildings, or portions thereof, undergoing demolition. I hereby declare that demolition authorized by this permit is from construction that (does) (does not) contain asbestos, or that no demolition is authorized by this permit.
 I certify that I have read this application and affirm under penalty of perjury that the above information is correct. I agree to comply with all local Ordinances and State laws relating to building construction. I hereby authorize representatives of the County of Sonoma to enter upon the above-mentioned property for inspection purposes. If, after making the Certificate of Exemption for the Worker's Compensation provision of the Labor Code I should become subject to such provisions, I will forthwith comply. In the event I do not comply with the Workman's Compensation law, this permit shall be deemed revoked.
[Signature]
 PERMITTEE SIGNATURE
1560 Railroad Ave., St. Helena, 94574
 ADDRESS CITY ZIP
 Contractor Owner Other Licensed Professional

Work Authorized: Tasting Room Remodel / Office & Conference room addition

<input checked="" type="checkbox"/> Plans Approved	<input type="checkbox"/> Post FIRM	<input type="checkbox"/> Alquist Priolo Report Available
<input type="checkbox"/> No Plans Subject to Field Inspection	<input type="checkbox"/> Pre FIRM	<input type="checkbox"/> Geotechnical report Available

Plan Check Cleared By: [Signature] Date: 10/6/14 Type of Construction: VB Occupancy: BA2M No. of Stories: 2 No. of Bedrooms: N/A
 Permit Cleared for Issuance By: [Signature] Date: 11/2/14 Auto. Fire Sprinklers Req'd: _____ No. of Units: _____ Certificate of Occupancy: _____

PAYMENT REC'D

Machine Space for Permit Fee

\$ 60

NOV 24 2014

PERMIT AND RESOURCE MANAGEMENT DEPARTMENT
 COUNTY OF SONOMA

JOB ADDRESS: 4401 SLUSSER RD. SRO
 PERMIT NUMBER: BLD 14-2815
 INSPECTION AREA: 8

SPECIAL INSPECTION REQUIRED		<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO	IF YES, SEE ADDITIONAL SHEET
INSPECTION RECORD	DATE	NAME	REMARKS	
101) ROUGH GRADING			(103) Footings for office addition o.k.	
103) FOUNDATION	2-3-15	KM	1-28-15 KM	
FORMS/SETBACK			(105) Slab for office addition o.k.	
FOOTING			(109) Footings for retain wall o.k.	
WALLS			1-28-15 KM	
106) UFER GROUND #			(116) office addition o.k. 1-28-15 KM	
104) CAISSONS/PIERS				
105) SLAB	2-3-15	KM		
107) UNDERGROUND UTILITIES				
110) MASONRY				
109) RETAINING WALLS	2-2-15	KM	(109) wall steel o.k. to pour 2-2-15 KM	
113) FIREPLACE				
FOOTING			(140) Framing for parapet extension o.k.	
HEARTH/PROTECTION			4-16-15 KM	
THROAT				
114) CHIMNEY				
120) UNDERFLOOR/UNDERSLAB				
115) HYDRONICS				
116) U/F ELECTRICAL	3-3-15	KM		
117) U/F MECHANICAL				
118) U/F PLUMBING				
119) U/F FRAMING				
139) U/F INSULATION				
126) SHEAR WALLS	3-3-15	KM		
<input checked="" type="checkbox"/> INTERIOR	<input checked="" type="checkbox"/> EXTERIOR			
127) DIAPHRAGMS	2-13-15	MW		
<input checked="" type="checkbox"/> ROOF	<input type="checkbox"/> FLOOR			
134) SIDING/SHEATHING				
125) HOLD DOWNS				
132) CLOSE-IN	3-6-15	KM		
122) ROUGH ELECTRICAL	3-3-15	KM		
123) ROUGH MECHANICAL	3-3-15	KM		
124) ROUGH PLUMBING	2-6-15	MW		
128) ROUGH FRAME	3-3-15	KM		
160) SMOKE DETECTORS				
139) INSULATION				
142) WALLBOARD	3-9-15	KM		
143) FIREWALLS				
135) STUCCO/PLASTER				
<input type="checkbox"/> LATH	<input type="checkbox"/> SCRATCH			
137) ROOFING				
130) TUB/SHOWER PAN				
162) FIRE DAMPERS/DOORS				
164) SUSPENDED CEILING				
<input type="checkbox"/> ROUGH ELEC.	<input type="checkbox"/> ROUGH MECH.			
165) EXITING - RAMPS/STAIRS				
163) HANDRAILS/GUARDRAILS				
CORRIDORS/DOORS				
166) ACCESSIBILITY COMPLIANCE			650) SUSMP INSPECTION	
144) WATER TANKS			651) NPDES EROSION COMPLIANCE	
<input type="checkbox"/> SLAB	<input type="checkbox"/> WALLS		652) NPDES SEDIMENT COMPLIANCE	
170) TEMPORARY OCCUPANCY	4-30-15	KM	653) NPDES DOCS/SWPPP	
171) TEMPORARY ELECTRICAL			FIRE INSPECTION REQUIRED	
172) TEMPORARY GAS			<input type="checkbox"/> Yes <input type="checkbox"/> No	
174) ELECTRIC METER AUTHORIZATION			759) KNOX BOX	
152) PANEL BOARDS/SERVICE			760) PROPANE TANK HOLD DOWNS	
189) SEPTIC ELECTRIC FINAL			770) SPRINKLER FINAL	
175) GAS METER AUTHORIZATION			771) ABOVEGROUND HYDROSTATIC	
153) GAS PRESSURE TEST	3-12-15	KM	772) UNDERGROUND HYDROSTATIC	
HOUSE			773) UNDERGROUND FLUSH	
YARD			774) THRUST BLOCKS	
190) MANUF. HOME FOUNDATION			775) PIPE WELD	
191) MANUF. HOME INSTALLATION			776) HYDRANTS/APPLIANCES	
CONTINUITY			777) PUMP ACCEPTANCE	
STAIRS/SKIRTS			778) WATER SUPPLY/TANK	
RIDGE BOLTING			779) ALARM SYSTEM	
193) MANUF. HOME COND. FINAL			780) HOOD & DUCT SYSTEM	
SWIMMING POOLS			781) ABOVEGROUND TANK/DISPENSER	
194) PRE-GUNITE			198) FIRE FINAL	
195) PRE-DECK			CLEARANCES:	
196) PRE-PLASTER/FENCE			FIRE <input type="checkbox"/> Local <input type="checkbox"/> County	
197) VINYL/FIBERGLASS POOL EXCAVATION			HEALTH DEPARTMENT	
102) GRADING FINAL			ZONING	
176) ELECTRICAL FINAL	11-30-15	KM	SANITATION	
177) MECHANICAL FINAL	11-30-15	KM		
178) PLUMBING FINAL	11-30-15	KM		
199) FINAL	11-30-15	KM		
OCCUPANCY (OK TO OCCUPY)			PLAN RETENTION REQUIRED?	
			<input type="checkbox"/> Yes <input type="checkbox"/> No	

PERMIT #

SONOMA=CUTRER

VINEYARDS

August 1, 2015

Re: Rubber track strips at Nana Wall in tasting room

Rubber strips need to be inserted in the tracks at the Nana Wall entrance to the Sonoma-Cutrer Tasting room at all times. When the Nana wall is in the completely open configuration additional rubber strips are located in the closet at the rear of the large tasting room that are to be placed in the tracks until the Nana Wall is closed.

RETAIN

COUNTY OF SONOMA - PERMIT AND RESOURCE MANAGEMENT DEPARTMENT

2550 Ventura Avenue, Santa Rosa, CA 95403 (707) 565-1900 FAX (707) 565-1103

Application for: **Temporary Occupancy** **Temporary Electric for Construction**
 Temporary Gas Meter Set **Temporary Electric Meter Set**

This permit does not constitute approval for occupancy until structure has been inspected and approved.
 INFORMATION WITHIN HEAVY LINE TO BE COMPLETED BY APPLICANT

SITE LOCATION INFORMATION - PRINT CLEARLY																		
Site Address: <u>4401 Slusser Rd.</u>		City: <u>Windsor</u> ZIP: <u>95492</u>																
Cross-Street: <u>River Rd</u>	APN: <u>087-070-031</u>	Project Phone #: <u>(707) 237-3441</u>	Project Fax #: ()															
Directions:	Subd. Name	Unit #	Lot #															
OWNER INFORMATION		CONTRACTOR INFORMATION																
Name: <u>Sonoma Outlier Vineyards</u>		Company Name:																
Mailing Address:		Address:																
City:	State:	ZIP:																
Day Ph: ()	Fax: ()	Day Ph: ()	Fax: ()															
<p style="text-align: center;">OWNER-BUILDER DECLARATION</p> <p>I hereby affirm under penalty of perjury that I am exempt from the Contractor's License Law for the following reason (Sec. 7031.5, Business and Professions Code: Any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractor's License Law (Chapter 9 (commencing with Section 7000) of Division 3 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500).):</p> <p><input type="checkbox"/> I, as owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044 Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his or her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he or she did not build or improve for the purpose of sale.)</p> <p><input type="checkbox"/> I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law.)</p> <p><input type="checkbox"/> I am exempt under Sec. _____, B & P.C. for this reason _____</p> <p>Date: <u>4-29-15</u> Owner: <u>[Signature]</u></p> <p>I certify that I have read this application and affirm under penalty of perjury that the above information is correct. I agree to comply with all local Ordinances and State laws relating to building construction. I hereby authorize representatives of the County of Sonoma to enter upon the above-mentioned property for inspection purposes. If, after making the Certificate of Exemption for the Worker's Compensation provision of the Labor Code I should become subject to such provisions, I will forthwith comply. In the event I do not comply with the Workman's Compensation law, this permit shall be deemed revoked.</p> <p><u>[Signature]</u> PERMITTEE SIGNATURE</p> <p><u>4401 Slusser Rd. Windsor 95492</u> ADDRESS CITY ZIP</p> <p><input type="checkbox"/> Contractor <input checked="" type="checkbox"/> Owner <input type="checkbox"/> Other (Licensed Professional, etc.)</p>		<p style="text-align: center;">WORKER'S COMPENSATION DECLARATION</p> <p>I hereby affirm under penalty of perjury one of the following declarations:</p> <p><input type="checkbox"/> I have and will maintain a certificate of consent to self-insure for worker's compensation, as provided for by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued.</p> <p><input type="checkbox"/> I have and will maintain worker's compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My worker's compensation insurance carrier and policy number are:</p> <p>Carrier _____ Policy No. _____</p> <p>(This section need not be completed if the permit is for one hundred dollars (\$100) or less.)</p> <p><input type="checkbox"/> I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the worker's compensation laws of California, and agree that if I should become subject to the worker's compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.</p> <p>Exp. Date: _____ Applicant: _____</p> <p>WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL, AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000), IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST, AND ATTORNEY'S FEES.</p>																
<p style="text-align: center;">LICENSED CONTRACTOR'S DECLARATION</p> <p>I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with Section 7000) of Division 3 of the Business and Professions Code, and my license is in full force and effect.</p> <p>Lic. Class _____ Lic. No. _____</p> <p>Exp. Date _____ Contractor _____</p>		<p style="text-align: center;">APPROVALS FOR DEPARTMENT USE</p> <p>Zoning: <u>S-Swede</u> <u>[Signature]</u> <u>1/7/14</u> Approved by: _____ Date: _____</p> <p>Sewer Connection: <input type="checkbox"/> Available <input type="checkbox"/> Fees Paid</p> <p>Approved by: _____ Date: _____</p> <p>Septic System Permit/Clearance # _____</p> <p>Approved by: <u>[Signature]</u> Date: <u>4/29/15</u></p> <p>Fire: <u>[Signature]</u> Date: <u>4/29/15</u></p> <p>Code Enforcement Violation <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Violation # _____</p> <p>This permit is limited to _____ days.</p>																
<p style="text-align: center;">Permit Number: BLD 14-2815TEM Area: _____</p>																		
<p style="text-align: center;">INSPECTIONS</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 80%;">Inspection Type</th> <th style="width: 10%;">Inspector</th> <th style="width: 10%;">Date</th> </tr> </thead> <tbody> <tr> <td>Temporary Occupancy</td> <td></td> <td></td> </tr> <tr> <td>Temporary Electric for Construction</td> <td></td> <td></td> </tr> <tr> <td>Temporary Gas Meter Set</td> <td></td> <td></td> </tr> <tr> <td>Temporary Electrical Meter Set</td> <td></td> <td></td> </tr> </tbody> </table> <p>Conditions: <u>FIRE</u></p>				Inspection Type	Inspector	Date	Temporary Occupancy			Temporary Electric for Construction			Temporary Gas Meter Set			Temporary Electrical Meter Set		
Inspection Type	Inspector	Date																
Temporary Occupancy																		
Temporary Electric for Construction																		
Temporary Gas Meter Set																		
Temporary Electrical Meter Set																		
<p>Other: Approved by: <u>[Signature]</u> Date: _____</p>		<p>Permit Cleared for issuance by: <u>[Signature]</u> Date: <u>4/29/15</u></p>																

WHEN VALIDATED THIS IS YOUR PERMIT
 THROUGH _____ / _____ / _____

CERTIFICATE OF COMPLIANCE

(Page 1 of 4) LTG-1C


Project Name: SONOMA CUTTRER VINEYARDS		Date: 05-27-2014
Project Address: 4401 SLUSSER ROAD WINDSOR, CA 95492	Climate Zone:	Building CFA: Unconditioned Floor Area :

General Information

Building Type:	<input checked="" type="checkbox"/> Nonresidential	<input type="checkbox"/> High-Rise Residential	<input type="checkbox"/> Hotel/Motel	
	<input type="checkbox"/> Schools	<input type="checkbox"/> Relocatable Public Schools	<input checked="" type="checkbox"/> Conditioned Spaces	<input type="checkbox"/> Unconditioned Spaces
Phase of Construction:	<input type="checkbox"/> New Construction	<input checked="" type="checkbox"/> Addition	<input type="checkbox"/> Alteration	
Method of Compliance:	<input type="checkbox"/> Complete Building	<input checked="" type="checkbox"/> Area Category	<input type="checkbox"/> Tailored	


Documentation Author's Declaration Statement

- I certify that this Certificate of Compliance documentation is accurate and complete.

Name: RAY E SLAUGHTER	Signature: 
Company: RESA	Date:
Address: 3820 CYPRESS DRIVE, SUITE 1	If applicable: CEA # CEPE #
City/State/Zip: PETALUMA, CALIFORNIA 94954	Phone: (707)762-3310

Principal Lighting Designer's Declaration Statement

- I am eligible under Division 3 of the California Business and Professions Code to accept responsibility for lighting design.
- This Certificate of Compliance identifies the lighting features and performance specifications required for compliance with Title 24, pages 1 and 6 of the California Code of Regulations.
- This design features represented on this Certificate of Compliance are consistent with the information provided to document this design on the other applicable compliance forms, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.

Name: RAY E SLAUGHTER	Signature: 
Company: RESA	Phone: (707)762-3310
Address: 3820 CYPRESS DRIVE, SUITE 1	License # E10745
City/State/Zip: PETALUMA, CALIFORNIA 94954	Date: 6-30-2015

Lighting Mandatory Measures

Indicate location on building plans of Mandatory Measures Note Block:

E0.2

LIGHTING COMPLIANCE FORMS & WORKSHEETS (check box if worksheet is included)

For detailed instructions on the use of this and all Energy Efficiency Standards compliance forms, please refer to the Nonresidential Manual published by the California Energy Commission.

<input checked="" type="checkbox"/> LTG-1C Pages 1 through 4	Certificate of Compliance. All pages required on plans for all submittals.
<input type="checkbox"/> LTG-2C	Lighting Controls Credit Worksheet
<input checked="" type="checkbox"/> LTG-3C	Indoor Lighting Power Allowance
<input type="checkbox"/> LTG-5C Pages 1 through 4	Tailored Method Worksheet
<input type="checkbox"/> LTG-5C Pages 1 and 2	Line Voltage Track Lighting Worksheet

CERTIFICATE OF COMPLIANCE

(Page 3of4) **LTG-1C**

Project Name:

SONOMA CUTTRER VINEYARDS

Date:

05-27-2014

INDOOR LIGHTING SCHEDULE and FIELD INSPECTION ENERGY CHECKLIST

Fill in controls for all spaces: a) area controls, b) multi-level controls, c) manual daylighting controls for daylit areas > 250ft², automatic daylighting controls for daylit areas > 2,500ft², d) shut-off controls, e) display lighting controls, f) tailored lighting controls-general lighting controlled separately from display, ornamental and display lighting and g) demand responsive automatic controls for retail stores > 50,000ft², in accordance with Section 131.

MANDATORY LIGHTING CONTROLS-FIELD INSPECTION ENERGY CHECKLIST

Field Inspector

Type/Description	Number of Units	Location in Building	Field Inspector	
			Pass	Fail
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>

Field Inspector's Notes or Discrepancies:

FORSYTHE

ENGINEERING CONSULTANTS

County of Sonoma
Permit & Resource Management Dept.
c/o Building Inspection
2550 Ventura Avenue
Santa Rosa, CA 94403-2829

Date: March 3, 2015

PERMIT#
BLD14-2815

PROJECT:
Sonoma Cutrer Winery
4401 Slusser Road
Windsor, CA

SUBJECT: FINAL SPECIAL INSPECTION LETTER

This is to certify that in accordance with Section 17 of the California Building Code, we have provided the Special Inspections summarized below:

1. **Pull/Tension Tests**
#4 (180) rebar, 10% tested
5/8" (12) 6" embed, 2 tested
No failures noted
(as per detail 7/S1.1)


2. **Shear Wall Nailing/ Holdowns/Titen Anchors**
Shear walls were nailed off as per Shear Wall Schedule
Holdowns & Shear wall types were as per plans with proper nailing and hardware as required
Remodel – Line F, added shear
6" titans installed as per specifications
Building addition – Line 9.5-B, 11-A, 14-A, G9-A
HD8 (B), HD2 (A) holdowns installed

3. **Reinforced Concrete Placement & Sampling (lab strength results attached)**
Footings, Slab

Based upon inspections performed and our substantiating reports, it is our professional judgment that, to the best of our knowledge, the inspected work was performed in accordance with the approved plans, specifications, and applicable workmanship provisions of the California Building Code.

Very truly yours,

Charles J. Roberts
Chief Engineer
RCE no. C-038692, Exp. 3/31/15



FORSYTHE

ENGINEERING CONSULTANTS

LABORATORY TEST REPORT

COMPRESSIVE STRENGTH


PROJECT: Sonoma Cutrer Winery
4401 Slusser Road
Windsor, CA


Concrete temp: 57
Concrete slump: 4 3/4"
Outside temp: 40

Cast by: B. Forsythe
Test Standard: ASTM C39
Sample Size: 4" X 8" concrete

Cast Date fc req'd.	Structure & Location	Lab. No.	Test Date	Age Days	Area sq in	Max. Load	Strength [fc] (PSI)
1/29/2015 3000	Footings, Slab	178	02/05/15	7	12.56	29,510	2,350
		179	02/26/15	28	12.56	47,570	3,790
		180	02/26/15	28	12.56	48,110	3,830
	Average of both 28 day breaks: 3810	181		sp	12.56		

The tests reported herein were conducted in accordance with ASTM requirements and under the supervision of a licensed professional Engineer. All samples are wet cured as required until test date.


Barry Forsythe
Laboratory Manager


Charles J. Roberts
RCE no. C-038692, Exp. 3-31-15