

E
Type

✓
Plans

SEP14-0655

Permit Number

2335

Street Number

Willow Creek Rd

Street Name

Ten

Community Code

097-210-006

APN

Application is hereby made to the Permit & Resource Management Department for a permit to construct or repair a sewage disposal system as described below in compliance with code of Sonoma County or for clearance for other construction.

APPLICANT: PLEASE PRESS HARD (USE BLACK INK).
FILL IN BETWEEN HEAVY LINES ONLY.
SEE BACK SIDE FOR TERMS OF PERMIT

This permit application must be signed on pertinent signature lines by the same person (i.e., contractor or owner/builder.) A letter of authorization from the owner must accompany this application if an agent is signing on the owner's behalf.

Building PERMIT # SEP14-0655 EXISTING USE(S) ON SITE:

JOB ADDRESS 2335 WILLOW CREEK RD.

NEAREST CROSS STREET CA HWY 1

ASSESSOR'S PARCEL NO. 097-210-006

SUBDIVISION N/A LOT - LOT - ZIP 96450

CITY JENNER, CA

SEWAGE DISPOSAL SYSTEM CONTRACTOR

ADDRESS T6D PHONE No.

GENERAL CONTRACTOR

OWNER'S NAME GORDON P. MATTHEWS

MAILING ADDRESS 301 MAIN ST. # 346

CITY SAN FRANCISCO STATE CA ZIP 94105

PHONE (415) 601-1863

INSTALLATION WILL SERVE: ☐ EXISTING RESIDENCE ☐ NEW RESIDENCE

☐ REPLACEMENT RESIDENCE ☒ SECOND UNIT ☐ COMMERCIAL ☐ REPAIR

☒ OTHER: Guest House ☐ ATTACHED CONDITIONAL STATEMENT

TOTAL (Existing + Proposed) Total No. of Units: 2 4
Water Supply: ☐ Public ☒ Private
Lot Size:

OWNER-BUILDER DECLARATION

I hereby affirm under penalty of perjury that I am exempt from the Contractor's License Law for the following reason (Sec. 7031.5, Business and Professions Code): Any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractor's License Law (Chapter 9 (commencing with Section 7000) of Division 3 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.);

☐ I, as owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044 Business and Professions Code). The Contractor's License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his or her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he or she did not build or improve for the purpose of sale.)

☐ I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code). The Contractor's License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractor's License Law.

☒ I am exempt under Sec. 7031.5 B & P.C. for this reason: ULI, ENB

Date 11.20.11

Owner

I certify that I have read this application and affirm under penalty of perjury that the above information is correct. I agree to comply with all local Ordinances and State laws relating to building construction. I hereby authorize representatives of the County of Sonoma to enter upon the above-mentioned property for inspection purposes. If, after making the Certificate of Exemption for the Worker's Compensation provision of the Labor Code I should become subject to such provisions, I will forthwith comply. In the event I do not comply with the Workman's Compensation law, this permit shall be deemed revoked.

Layout Plan Approved by: Adrienne Walker Date 12/17/11

LICENSED CONTRACTOR'S DECLARATION

I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with Section 7000) of Division 3 of the Business and Professions Code, and my license is in full force and effect.

Contractor License Class

License Number Expiration Date

A SEPTIC PERMIT SHALL EXPIRE IN THREE(3) YEARS FROM DATE OF ISSUANCE UNLESS OTHERWISE NOTED BY CODE ENFORCEMENT.

THIS PERMIT IS LIMITED TO DAYS.

Violation #

SONOMA COUNTY
CODE ENFORCEMENT
PERMIT AND RESOURCE
MANAGEMENT DEPARTMENT

Date

REVIEWED BY

I agree to comply with all local Ordinances and State laws relating to building construction. I hereby authorize representatives of the County of Sonoma to enter upon the above-mentioned property for inspection purposes. If, after making the Certificate of Exemption for the Worker's Compensation provision of the Labor Code I should become subject to such provisions, I will forthwith comply. In the event I do not comply with the Workman's Compensation law, this permit shall be deemed revoked.

Signature of Applicant
Date 12/17/11

WORKER'S COMPENSATION DECLARATION

I have and will maintain worker's compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My worker's compensation insurance carrier and policy number are:

Carrier Policy No. N/A

(This section need not be completed if the permit is for one hundred dollars (\$100) or less.)
I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the worker's compensation laws of California, and agree that if I should become subject to the worker's compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Exp. Date N/A
Warning: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL, AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000), IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST, AND ATTORNEY'S FEES.

☐ Contractor
☐ Owner
☒ Other Licensed Professional

SANTA ROSA CA

City

Date 11/5/15

HOGAN LAND SERVICES

A CALIFORNIA CORPORATION

September 28, 2015

HLS#1126

Attn: Raymond Yim
PRMD, Well and Septic Division
2550 Ventura Ave.
Santa Rosa, CA 95403

Site: 2335 Willow Creek Road
APN: 097-210-006

Subject: *Obs by*
Final Letter – SEP14-0065 Tank Only

Attachments:

- PRMD Inspection Report
- Engineer's Daily Inspection Report

Dear Raymond,


On April 15, 2015, Adrienne Walker, PRMD and I met at the site to check the new tank installation. During our inspection we observed that the septic tank was water tight and that the tank was fitted with risers and sanitary tees. We observed that the supply line was sleeved under the driveway and buried with 4' of cover at the water swale crossing. Also, we observed the passing hydraulic test of the pressure line to the existing tank under generator power.

On September 22, 2015, we met at the site for the final inspection. During our inspection we observed the permanent power and control panel and set the floats. The dose was set for 200 gallons with the high water alarm set to trigger just above the pump on. The floats and the high water alarm were tested and functioned properly.

Based on our inspections and the inspection conducted with PRMD, we determine that the guest house septic tank and dosing pump system are installed as designed and are in substantial conformance with Well and Septic Division of Sonoma County PRMD standards and the approved plans. We recommend the permit be finalized pending the electrical 189 approval for the control panel wiring.

If you have any questions or need additional information please feel free to call me.

Sincerely,



Daniel P. Byrne, RCE 80078

"We'll Get The Permit"

1702 4th Street • Santa Rosa, CA 95404 • 707.544-2104 • F 707.522.2105 • hoganls.com
Surveying • Civil & Structural Engineering • Construction Management • Violation Resolution

County of Sonoma
Permit & Resource Management Department
Well & Septic Section
2550 Ventura Avenue, Santa Rosa, CA 95403-2829
(707) 565-1900

SEPTIC SYSTEM INSPECTION

Site Address: 2335 Willow Creek Rd JEN
Owner: GORDON P. MATTHEWS

REQUEST FOR INSPECTION

Date of call: 9.23.15 Time: _____
Caller: HOUND LAND SERVICES
Caller's Phone No.: _____
Remarks: SEPIV-0655
TALK ONLY
Call taken by: RAYMOND YIM

INSPECTION NOTICE

- ☐ Stop work immediately - Call Environmental Health Specialist
Telephone _____ Hours _____
☐ OK to cover leachfield ☐ tank
☒ Provide Engineer's letter of approval
☒ Provide "As Built" plan to scale
☐ Call for inspection on pump & alarm
☐ Corrections needed - see remarks below
☐ OK to cover with Engineer's approval
☐ Issue Operational Permit

For further information call: RAYMOND 7/565-1940
Hours & Day: 1530 9.24.15
Remarks: PUMP/FWOT/ALARM WORK
DOSE SET=115 GPM
WFIMSL NO: AS-BUILT ENGR'S LTR
REINSPECTION FEE: 189

Ray Yim REHS 9.24.15
Environmental Health Specialist's Signature Date

Received by: [Signature]
Contractor's Signature

☐ Posted

County of Sonoma
Permit & Resource Management Department
Well & Septic Section
2550 Ventura Avenue, Santa Rosa, CA 95403-2829
(707) 565-1900

SEPTIC SYSTEM INSPECTION

Site Address: 2335 Willow Creek Rd
Owner: _____

REQUEST FOR INSPECTION

Date of call: _____ Time: _____
Caller: _____
Caller's Phone No.: _____
Remarks: Check floats, fees in tank
changed float distances. Check ^{clouds}
Need reinspection fees.
Call taken by: _____

INSPECTION NOTICE

- ☐ Stop work immediately - Call Environmental Health Specialist
Telephone _____ Hours _____
☐ OK to cover leachfield ☒ tank
☒ Provide Engineer's letter of approval
☒ Provide "As Built" plan to scale
☒ Call for inspection on pump & alarm
☐ Corrections needed - see remarks below
☐ OK to cover with Engineer's approval
☐ Issue Operational Permit

For further information call: _____
Hours & Day: _____

Remarks: Tank passed watertight
test. Slewed under driveway.
8" Pipe buried 4' under water
swale crosses pipe Risers
in place. 1200 gallon tank,
saw hydrolic test, saw test.

Colleen Walker 4/2/15
Environmental Health Specialist's Signature Date

Received by: [Signature]
Contractor's Signature

☐ Posted

NEED REINSPECTION FEE PAID. NEED AS-BUILT AND ENGINEERS LETTER. NEED INSPECTION FOR FOR PUMP (DOSE, FLOATS, ECT) AND ALARM.

1200 GALLON SEPTIC TANK INSTALLED. RISERS IN PLACE, TEES ON SITE. TANKS PASSED WATERTIGHTNESS TEST. SLEEVED UNDER DRIVEWAY. PIPE BURIED 4 FEET WHERE WATER SWALE CROSSES PIPE. SAW HYDRAULIC TEST.

FB
1/2

LANDS OF MATTHEWS
TANK ONLY FOR 2ND UNIT ADDITION AS BUILT
2335 WILLOW CREEK RD. JENNER
APN: 097-210-006

GENERAL NOTES

1. CONSULT LOCAL LAND SERVICES (944-2104) AND SONOMA COUNTY PUBLIC WORKS DEPT. FOR ALL NECESSARY PERMITS, REGULATIONS, AND ORDINANCES.
2. ALL TANKS SHALL BE SIZED ACCORDING TO PLANT AND LAND CAPACITY. ALL TANKS SHALL BE SIZED ACCORDING TO THE LATEST EDITION OF THE CEC AND THE SONOMA COUNTY CODE.
3. ALL TANKS SHALL BE SIZED ACCORDING TO THE LATEST EDITION OF THE CEC AND THE SONOMA COUNTY CODE.
4. ALL MATERIALS AND WORKMANSHIP SHALL CONFORM TO THE REQUIREMENTS OF THE PERMIT AND RESOURCE MANAGEMENT ACT (RMA) AND THE SONOMA COUNTY CODE.
5. THE CONTRACTOR SHALL BE SOLELY RESPONSIBLE FOR LOCATING AND MARKING UTILITY LINES IN THE WORK AREA.
6. DRAINAGE PROCEDURES USED IN CONNECTION WITH THE PROJECT SHALL BE SIZED ACCORDING TO THE LATEST EDITION OF THE CEC AND THE SONOMA COUNTY CODE.
7. ALL SEPTIC TANKS AND SEPTIC SYSTEMS SHALL BE SIZED ACCORDING TO THE LATEST EDITION OF THE CEC AND THE SONOMA COUNTY CODE.
8. THIS SEPTIC DISPOSAL SYSTEM HAS BEEN DESIGNED TO ACCOMMODATE A PEAK DAILY FLOW OF 120 GALLONS PER PERSON PER DAY. WITH WATER USER LIMITS FOR FLOW TOLERANCE (1.6 GALLONS MINIMUM PER PERSON) AND FLOW TOLERANCE (1.6 GALLONS MINIMUM PER PERSON).

STAGES TO BE INSPECTED

CONTRACTOR IS REQUIRED TO HAVE ENGINEER AND/OR ENVIRONMENTAL HEALTH SPECIALIST INSPECT THE CONSTRUCTION AT THE FOLLOWING STAGES:

1. PRELIMINARY INSPECTION OF THE CONSTRUCTION SITE.
2. INSPECTION OF THE CONSTRUCTION SITE.
3. INSPECTION OF THE CONSTRUCTION SITE.
4. INSPECTION OF THE CONSTRUCTION SITE.
5. INSPECTION OF THE CONSTRUCTION SITE.
6. INSPECTION OF THE CONSTRUCTION SITE.
7. INSPECTION OF THE CONSTRUCTION SITE.
8. INSPECTION OF THE CONSTRUCTION SITE.
9. INSPECTION OF THE CONSTRUCTION SITE.
10. INSPECTION OF THE CONSTRUCTION SITE.

ELECTRICAL NOTES

1. ALL ELECTRICAL CONNECTIONS AND SPECIFICATIONS SHALL MEET THE REQUIREMENTS OF THE NATIONAL ELECTRICAL CODE (NEC) AND THE SONOMA COUNTY CODE.
2. ALL ELECTRICAL CONNECTIONS SHALL BE MADE IN ACCORDANCE WITH THE REQUIREMENTS OF THE NATIONAL ELECTRICAL CODE (NEC) AND THE SONOMA COUNTY CODE.
3. ALL ELECTRICAL CONNECTIONS SHALL BE MADE IN ACCORDANCE WITH THE REQUIREMENTS OF THE NATIONAL ELECTRICAL CODE (NEC) AND THE SONOMA COUNTY CODE.
4. ALL ELECTRICAL CONNECTIONS SHALL BE MADE IN ACCORDANCE WITH THE REQUIREMENTS OF THE NATIONAL ELECTRICAL CODE (NEC) AND THE SONOMA COUNTY CODE.
5. ALL ELECTRICAL CONNECTIONS SHALL BE MADE IN ACCORDANCE WITH THE REQUIREMENTS OF THE NATIONAL ELECTRICAL CODE (NEC) AND THE SONOMA COUNTY CODE.
6. ALL ELECTRICAL CONNECTIONS SHALL BE MADE IN ACCORDANCE WITH THE REQUIREMENTS OF THE NATIONAL ELECTRICAL CODE (NEC) AND THE SONOMA COUNTY CODE.
7. ALL ELECTRICAL CONNECTIONS SHALL BE MADE IN ACCORDANCE WITH THE REQUIREMENTS OF THE NATIONAL ELECTRICAL CODE (NEC) AND THE SONOMA COUNTY CODE.
8. ALL ELECTRICAL CONNECTIONS SHALL BE MADE IN ACCORDANCE WITH THE REQUIREMENTS OF THE NATIONAL ELECTRICAL CODE (NEC) AND THE SONOMA COUNTY CODE.
9. ALL ELECTRICAL CONNECTIONS SHALL BE MADE IN ACCORDANCE WITH THE REQUIREMENTS OF THE NATIONAL ELECTRICAL CODE (NEC) AND THE SONOMA COUNTY CODE.
10. ALL ELECTRICAL CONNECTIONS SHALL BE MADE IN ACCORDANCE WITH THE REQUIREMENTS OF THE NATIONAL ELECTRICAL CODE (NEC) AND THE SONOMA COUNTY CODE.

EROSION AND SEDIMENT CONTROL

1. EROSION AND SEDIMENT CONTROL MEASURES SHALL BE INSTALLED AND MAINTAINED THROUGHOUT THE CONSTRUCTION PROCESS.
2. EROSION AND SEDIMENT CONTROL MEASURES SHALL BE INSTALLED AND MAINTAINED THROUGHOUT THE CONSTRUCTION PROCESS.
3. EROSION AND SEDIMENT CONTROL MEASURES SHALL BE INSTALLED AND MAINTAINED THROUGHOUT THE CONSTRUCTION PROCESS.
4. EROSION AND SEDIMENT CONTROL MEASURES SHALL BE INSTALLED AND MAINTAINED THROUGHOUT THE CONSTRUCTION PROCESS.
5. EROSION AND SEDIMENT CONTROL MEASURES SHALL BE INSTALLED AND MAINTAINED THROUGHOUT THE CONSTRUCTION PROCESS.
6. EROSION AND SEDIMENT CONTROL MEASURES SHALL BE INSTALLED AND MAINTAINED THROUGHOUT THE CONSTRUCTION PROCESS.
7. EROSION AND SEDIMENT CONTROL MEASURES SHALL BE INSTALLED AND MAINTAINED THROUGHOUT THE CONSTRUCTION PROCESS.
8. EROSION AND SEDIMENT CONTROL MEASURES SHALL BE INSTALLED AND MAINTAINED THROUGHOUT THE CONSTRUCTION PROCESS.
9. EROSION AND SEDIMENT CONTROL MEASURES SHALL BE INSTALLED AND MAINTAINED THROUGHOUT THE CONSTRUCTION PROCESS.
10. EROSION AND SEDIMENT CONTROL MEASURES SHALL BE INSTALLED AND MAINTAINED THROUGHOUT THE CONSTRUCTION PROCESS.

SURVEY NOTES

TOPOGRAPHIC SURVEYING USED IN THIS DESIGN WAS PROVIDED BY HOGAN LAND SERVICES. THE SURVEYING DATA IS BASED ON THE FOLLOWING ASSUMPTIONS:

1. THE SURVEYING DATA IS BASED ON THE FOLLOWING ASSUMPTIONS.
2. THE SURVEYING DATA IS BASED ON THE FOLLOWING ASSUMPTIONS.
3. THE SURVEYING DATA IS BASED ON THE FOLLOWING ASSUMPTIONS.
4. THE SURVEYING DATA IS BASED ON THE FOLLOWING ASSUMPTIONS.
5. THE SURVEYING DATA IS BASED ON THE FOLLOWING ASSUMPTIONS.
6. THE SURVEYING DATA IS BASED ON THE FOLLOWING ASSUMPTIONS.
7. THE SURVEYING DATA IS BASED ON THE FOLLOWING ASSUMPTIONS.
8. THE SURVEYING DATA IS BASED ON THE FOLLOWING ASSUMPTIONS.
9. THE SURVEYING DATA IS BASED ON THE FOLLOWING ASSUMPTIONS.
10. THE SURVEYING DATA IS BASED ON THE FOLLOWING ASSUMPTIONS.

NOTES TO OWNER, CONTRACTOR, & OTHERS

1. NOTIFICATION OF THIS DESIGN SHALL BE PROVIDED TO THE OWNER BY THE ENGINEER. THE OWNER SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS.
2. THE ENGINEER'S DESIGN IS BASED ON THE FOLLOWING ASSUMPTIONS:
3. THE ENGINEER'S DESIGN IS BASED ON THE FOLLOWING ASSUMPTIONS.
4. THE ENGINEER'S DESIGN IS BASED ON THE FOLLOWING ASSUMPTIONS.
5. THE ENGINEER'S DESIGN IS BASED ON THE FOLLOWING ASSUMPTIONS.
6. THE ENGINEER'S DESIGN IS BASED ON THE FOLLOWING ASSUMPTIONS.
7. THE ENGINEER'S DESIGN IS BASED ON THE FOLLOWING ASSUMPTIONS.
8. THE ENGINEER'S DESIGN IS BASED ON THE FOLLOWING ASSUMPTIONS.
9. THE ENGINEER'S DESIGN IS BASED ON THE FOLLOWING ASSUMPTIONS.
10. THE ENGINEER'S DESIGN IS BASED ON THE FOLLOWING ASSUMPTIONS.

WELL & SEPTIC HISTORY

THE EXISTING 3" BOREHOLE SEPTIC SYSTEM IS SERVED BY A DWP SYSTEM SIZED FOR 4 PERSONS. THE PROPOSED 1" BOREHOLE SEPTIC SYSTEM IS SERVED BY A DWP SYSTEM SIZED FOR 4 PERSONS.


SEPTIC-1-0175 SITE PLAN AND DWP INFORMATION

SEPTIC-1-0175 ADDITIONAL/REMARKS - NON STANDARD DWP SYSTEM

SHEET INDEX

SHEET 1 SYSTEM NOTES

SHEET 2 SYSTEM PLAN & DETAILS



NOTE: THIS DESIGN DOES NOT REPRESENT A TOPOGRAPHIC SURVEY OR BOUNDARY DETERMINATION. BOUNDARY SURVEY IS THE ASSUMED RESPONSIBILITY OF THE OWNER AND HAS NOT BEEN CONDUCTED OR COMPLETED.

SEWAGE DISPOSAL SYSTEM
DRIP SYSTEM NOTES

2335 WILLOW CREEK ROAD
JENNER, CALIFORNIA

HOGAN LAND SERVICES
A CALIFORNIA CORPORATION

1702 4TH STREET
SANTA ROSA, CA 95404

www.hoganla.com

Tel (707) 544-2104
Fax (707) 522-2105


DRN: 0838A
CHK: DBS
PM: DBS
DATE: 11/18/14
JOB #: 1128

THIS PLAN WAS PREPARED BY ME OR UNDER MY DIRECTION AT THE REQUEST OF CHURCH HILDRETH IN NOVEMBER 2014


D.P.B.
DANIEL P. BYRNE, RCE 80078

NOV 20 11

SEAL: DANIEL P. BYRNE, RCE 80078





AS BUILT



GRINDER PUMP ASSEMBLY DETAIL

ITEM	QTY	UNIT	PRICE	TOTAL
1. 1/2" DIA. 10' LONG 1" THICK CONCRETE PIPE	1	LF	12.00	12.00
2. 1/2" DIA. 10' LONG 1" THICK CONCRETE PIPE	1	LF	12.00	12.00
3. 1/2" DIA. 10' LONG 1" THICK CONCRETE PIPE	1	LF	12.00	12.00
4. 1/2" DIA. 10' LONG 1" THICK CONCRETE PIPE	1	LF	12.00	12.00
5. 1/2" DIA. 10' LONG 1" THICK CONCRETE PIPE	1	LF	12.00	12.00
6. 1/2" DIA. 10' LONG 1" THICK CONCRETE PIPE	1	LF	12.00	12.00
7. 1/2" DIA. 10' LONG 1" THICK CONCRETE PIPE	1	LF	12.00	12.00
8. 1/2" DIA. 10' LONG 1" THICK CONCRETE PIPE	1	LF	12.00	12.00
9. 1/2" DIA. 10' LONG 1" THICK CONCRETE PIPE	1	LF	12.00	12.00
10. 1/2" DIA. 10' LONG 1" THICK CONCRETE PIPE	1	LF	12.00	12.00



SYSTEM NOTES

1. INSTALL NEW 1200 CM AND APPROVED SEPTIC TANK, PUMP LOCATION TO BE DETERMINED AT TIME OF CONSTRUCTION.
2. INSTALL APPROPRIATE SAND PUMP FOR REMAINING SEPTIC TANK (7' MIN. SOLIDS CAPACITY) IN LEAD ONLY SIDE OF TANK. REFER TO ELECTRICAL NOTES AND DETAILS ON SHEET 1.
3. INSTALL 2" SCH 40 PRESSURE LINE WITH 2" COVER TO (R) BUILDING SEWER LINE. INSTALL TO MAINTAIN PREVENTION OF BACK FLOW INTO HOUSE.
4. EXISTING PRIMARY DRAIN FIELD INSTALLED UNDER SEPARATE PERMIT, SEP11-03A. 4 REMEDIAL CAPACITY INSULATION.
5. FILL OF 4 BEDROOMS AVAILABLE DRAINAGE AREA TO REMAIN UNCHANGED.

LEGEND

---	RECORD BOUNDARY LINE	6" DIA.	8" DIA.
---	FLOW LINE	8" DIA.	8" DIA.
---	EDGE OF GRAVEL ROAD	8" DIA.	8" DIA.
---	PRIMARY DRAIN LINE	8" DIA.	8" DIA.
---	RESERVE DRAIN LINE	8" DIA.	8" DIA.
---	DRAIN FIELD BOUNDARY	8" DIA.	8" DIA.
---	OVERHEAD WIRE	8" DIA.	8" DIA.
---	RESERVE DRAIN LINE	8" DIA.	8" DIA.
---	CLEAN-OUT	8" DIA.	8" DIA.
---	TO BE DETERMINED	8" DIA.	8" DIA.

SEWAGE DISPOSAL SYSTEM
DRIP SYSTEM PLAN

2335 WILLOW CREEK ROAD
JENNER, CALIFORNIA

APN: 097-210-008

HOGAN LAND SERVICES
A CALIFORNIA CORPORATION

1702 4TH STREET
SANTA ROSA, CA 95404

Tel (707) 544-2104
Fax (707) 622-2105
www.hogans.com

DRN: 083/BAJ
CHK: D83
PM: D83
DATE: 11/19/14
JOB #: 1128

THIS PLAN WAS PREPARED BY ME OR UNDER MY DIRECTION AT THE REQUEST OF CHURCH HILDRETH IN NOVEMBER 2014

DLPB
DANIEL P. BYRNE REG 80078

