

E

Type



Plans

SEP00-1632


Permit Number

6603

Street Number

Church St

Street Name



1. ALL MATERIALS, WORKMANSHIP AND CONSTRUCTION DETAILS SHALL BE IN ACCORDANCE WITH THE CONSTRUCTION REQUIREMENTS OF THE SONOMA COUNTY PUBLIC HEALTH DEPARTMENT.
2. ALL MECHANICAL AND PLUMBING WORK AND THE METHODS OF CONSTRUCTION AND INSTALLATION THEREOF SHALL CONFORM TO SONOMA COUNTY STANDARDS AND UNIFORM PLUMBING CODE AND NATIONAL ELECTRIC CODE AND TO ALL LOCAL, STATE, FEDERAL AND OTHER LAWS PERTAINING TO THIS WORK.

3. LEACH LINES PERFORATED PIPE AND TRENCH BOTTOMS TO BE INSTALLED
LEVEL AND ON CEMENTS WITH THE USE OF A TRANSIT. INSTALL 160
LINEAR FEET OF LEACH LINES. SEE DETAIL.
4. METAL POSTS, 24 INCHES LONG AND 1/2 INCH IN DIAMETER SHALL BE
PLACED AT THE DISTRIBUTION BOXES AND EVERY 50 FEET PLUS THE ENDS OF
THE LEACH LINES, 24 INCHES MAXIMUM COVER.

6. MAINTAIN A MINIMUM SETBACK FROM THE SEPTIC TANK AND/OR LEACH LINES OF 100 FEET TO ANY WELL OR PERENNIAL STREAM, 50 FEET TO ANY DRAINAGE COURSE AND 8 FEET TO ANY FOUNDATION, STRUCTURE OR ROADWAY.

7. ALL SEWER LINES FROM HOUSE TO SEPTIC TANK AND FROM TANK TO FIRST DISTRIBUTION BOX TO BE INSTALLED AT 2% MINIMUM SLOPE (1% FOR 4" INCH SEWER LINES).


- B) CLEAN OUTS TO BE INSTALLED ON THE SEWER AND EFFLUENT LINES AT 100 FEET MAXIMUM INTERVALS.

10. NO SYSTEM CONSTRUCTION IS TO OCCUR WHILE SOILS ARE MOIST OR WET

11. THIS MAP DOES NOT CONSTITUTE A BOUNDARY SURVEY.


12. PRIOR TO BACKFILLING OR COVERING WORK THE CONTRACTOR SHALL REQUEST INSPECTION AND GIVE ADEQUATE NOTICE (48 HOURS MINIMUM) TO THE SONOMA COUNTY PUBLIC HEALTH DEPARTMENT BY CALLING 707-895-8888. 565-1696

13. USE EXIST. SEPTIC TANK



ABANDON EXISTING LEACHLINES BY REMOVING PIPE AND DRAIN ROCK
AND COMPACT TRENCHES TO 90% NATIVE.

SONOMA COUNTY
PERMIT AND RESOURCE
MANAGEMENT DEPARTMENT
REVIEWED BY
W. Edman
12-7-02
DATE
WELL AND SEPTIC SECTION



by: Dale R. Davis
Davis "Perk" Testing
3460 Burnside Road
Sebastopol, CA 95472

[illegible]

2
PAGE 51

3.60 00-0617 AREA 3

Delord Lloyd owner/
RICHARD LLOYD BUILDER
(415) 488-4249

FLOOR PLAN BEFORE REMODEL

CHURCH STREET

SONOMA COUNTY
PERMIT AND RESOURCE
MANAGEMENT DEPARTMENT
REVIEWED BY

W. Edmon

12-7-00
DATE

WELL AND SEPTIC SECTION

