

B

Type

2

Docs

Plans

~~B-051557~~ B-051557

Building Permit Number

9488

Street Number

Mill Station Rd

Street Name

Community Code

061-100-007

APN

COUNTY OF SONOMA

THIS IS NOT A PERMIT MAILING ADDRESS

SURVEY

RELOCATION
 FIRE DAMAGE
 OTHER

FILE NO. _____

NAME George Jewell

JOB ADDRESS 4488 Mill Station Rd

CITY Dubois

CITY _____

TELE. NO. _____

PERCENTAGE OF REPAIR _____

FROM JOB ADDRESS _____

TO JOB ADDRESS _____

CITY _____

1. USE TYPE		2. TYPE OF CONSTRUCTION		9. ELECTRICAL			
A. SINGLE	A. FIRE RESISTIVE	B. HEAVY TIMBER		A. SERVICE	F. CON. <input type="checkbox"/> DUCT <input type="checkbox"/> CABLE <input type="checkbox"/>		
B. DUPLEX	C. ORDINARY MASONRY	D. LIGHT INCOMBUSTIBLE FRAME		B. LOAD CENTER	G. WATER		
C. APARTMENT	E. WOOD FRAME			C. SERVICE EQUIPMENT	H. OUTLETS		
D. VES.				D. APPLIANCE CIRCUITS	I. FIXTURES		
E. INDUSTRIAL				K.T. <input type="checkbox"/> BY <input type="checkbox"/>			
3. FOUNDATION		4. EXTERIOR		10. PLUMBING AND HEATING			
A. CONCRETE	A. STUCCO	G. T.G. <input type="checkbox"/>		A. SEW.	G. LAVATORY		
B. BRICK	B. BRICK	H. <input type="checkbox"/>		B. VENTS	H. SINK		
C. WOOD	C. STONE	I. CON.		C. CONNECTIONS	I. WASH TUB		
D. VIER	D. WOOD SHINGLE COMP.	J. BLOCK		D. TRAPS	J. WATER HEATER		
E. SLAB	E. SHAKE			E. SHOWER	K. WASHER		
5. STRUCTURAL		SIZE	SPACING	11. HEATING			
A. GIRDERS				GAS <input type="checkbox"/> OIL <input type="checkbox"/> ELEC. <input type="checkbox"/> WATER <input type="checkbox"/>			
B. JOISTS - 1ST FL.				OTHER			
C. JOISTS - 2ND FL.				A. FLUES	D. FURNACE		
D. 10" ST. - CEILING				B. VENTS	E. GIHP		
E. EXTERIOR STUCCO				C. STOVE			
F. EXTERIOR STUCCO				12. ROOM AND FINISH DETAIL			
G. ROOF RAFTERS				ROOM	MATERIAL	WALLS	CEILING
H. BEARING WALLS EXT.							
I. BEARING WALLS INT.							
6. ROOF		7. WINDOWS		13. GARAGE AND STORAGE			
A. SHINGLE WOOD	A. WIREGLASS			A. CARPORT	F. VENT		
B. SHINGLE ABS.	B. GLASS			B. GARAGE	G. LIGHTING		
C. SHINGLE COMP.	C.			C. FLOOR	H. OPENINGS		
D. BULK UP	D. BATH			D. FOUNDATION	I. ATTACHED		
E. METAL	E. BED			E. UNATTACHED			
F. TILE	F. KITCHEN						
8. FIRE PREVENTION							
A. COVERED PAS.	I. STANDPIPE						
B. EXITS	J. WEF						
C. B.B.D. FITS	K. SPRINKLER						
D. EQUIPMENT	L. ALARM						
E. HOSE	M. FLAMMABLE STORAGE						
F.	N. TUBS						
G.	O. FIRE ESCAPE						
H.	P.						

CORRECTION SHEET

STRUCTURAL

O.K. TO RELOCATE

REJECTED FOR RELOCATION

TERMITE CERTIFICATE REQUIRED. REMOVE ADDITIONS.
 REMOVE PORCHES. REMOVE ALL CHIMNEYS. PLOT PLAN
 FLOOR PLAN. REPAIR ALL DAMAGE DONE DURING RELOCATION
 FOUNDATION. GIRDERS. REPLACE ROTTED TIMBERS
 REPLACE LANDING. REPLACE PORCHES. RE-FINISH FLOORS
 ADDITIONAL WINDOW AREA REQUIRED IN
 RE-STUD. FIRE-BLOCKING REQUIRED. RE-SIDE
 RE-STUCCO. RAISE CEILING TO 7'6". RE-FRAME CEILING
 STRONG BACK CEILING JOISTS. INSTALL ATTIC SCUTTLE
 INSTALL KITCHEN RANGE VENT. REDECORATE INTERIOR
 PAINT. REDECORATE EXTERIOR. PAINT. STUC.
 SIDE. RE-FRAME ROOF. RE-ROOF. BRACE ROOF

PLUMBING

RE-PLUMB STRUCTURE TO CODE REQUIREMENTS
 REMOVE ALL GAS SPACE HEATER OUTLETS IN STRUCTURES.
 ALL HEATERS TO BE APPROVED VENTED TYPE.
 GAS SHUT-OFFS EACH OUTLET.
 RELOCATE AND VENT WATER HEATER TO CODE REQUIREMENTS.
 INSTALL 3/4" WATER SERVICE TO WATER HEATER.
 INSTALL 3/4" FULLWAY GATE VALVE ON COLD WATER OF HEATER.
 INSTALL FULLWAY GATE VALVE ON MAIN WATER SUPPLY.
 INSTALL ANGLE STOPS ON WATER SUPPLY TO FIXTURES.
 FILLER SPOUTS TO BE 1" ABOVE OVERFLOW RIM FIXTURE.
 1/2" SIPHON BALLCOCKS REQUIRED IN WATER CLOSETS.
 PLUMBING VENTS TO BE 10' FROM PROPERTY LINES OR MECHANICAL
 AIR INTAKE.

ELECTRICAL

ALL ELECTRICAL EQUIPMENT EXPOSED TO BE RAIN-TIGHT.
 100 AMP. RESIDENTIAL SERVICE REQUIRED.
 COMMERCIAL SERVICE REQUIRED. REWIRE COMPLETE.
 ADDITIONAL OUTLETS REQUIRED. REMOVE EXT'H. CORD.
 MAX. SPACING WALL PLUGS 12' WITH #12 WIRE & GROUNDED.

NOTES

Owner, recently built appl. processing plant is available that would. Building was rejected from state approval. Re-insuring slab is patched from fire and minor operation. Term. areas patched approximately 1/2" deep.

Building Inspection Dept. has no objection to reuse of slab. Owner had checked Dept. to be contacted since food is processed in building.

There are no usable bolts left in slab. Professional plans required for permit to be filed.

RECOMMENDATIONS

Slab may be able to be patched with epoxy process

INSPECTOR John D. Smith DATE 7-12-83