

August 27th, 2018/19  
Job No. 3476. 31

GREG HANNAN  
203 ROSS ROAD  
SANTA ROSA, CA 95407  
BD19-4249

Foundation Excavations  
Geotechnical Engineering Services  
during Construction  
Residence  
Larkfield Estates Subdivision

47 BRIGHTON COURT  
Larkfield, California

This letter confirms that we are providing geotechnical engineering services during construction for the subject project. We are providing our services in general accordance with you continuing services clause of our agreement dated December 4, 2017.

On 8/7/2019, we observed the foundation excavations for the residence. Based on our observations, we conclude that the completed excavations observed expose firm materials in general accordance with the intent of our recommendations. Our work has not included verifying that the foundation is excavated to the required dimensions or is located in accordance with the project plans. The footings may be backfilled to planned footing depths with lean concrete.

Note that we were not contacted to observe or test any of the grading operations. We can not comment on work which we have not been contacted to observe or test.

We trust this provides the information you require at this time. If you have questions, or wish to discuss this further, please call.

Yours very truly,

BAUER ASSOCIATES, INC.

*Travis J. Lopez*

\* THERE IS A SECTION  
AT BACK (NORTH) OF HOUSE  
WHERE WE DID NOT OBSERVE  
FIRM MATERIALS. WE UNDERSTAND  
THAT STRUCTURAL ENGINEER  
HAS DESIGNED REINFORCING TO  
SPAN WEAK.

Westside Center  
6470 Mirabel Road  
Post Office Box 460  
Forestville, CA 95436  
707.887.2505