



GEOTECHNICAL CONSULTANTS

Date 9/5/2019  
Job No. 3476.109

NICOLE FISH  
34225 PHIL GREENWOOD RD.  
ELK, CA 95432

BUD19-3662

Geotechnical Engineering Services  
during Construction  
Project Type RESIDENCE  
Project Location 173 WEMBLEY CT.  
SANTA ROSA, California

This letter confirms that we are providing geotechnical engineering services during excavation of foundations for the subject project. We are providing our services on a time and expense basis, in accordance with our agreement dated 2/1/2018. We cannot comment on work which we have not been contacted to observe or test.

On 9/5/2019, we observed the foundation excavations for: RESIDENCE

Based on our observations, we conclude that the completed excavations observed expose firm materials in general accordance with the intent of our recommendations and those presented in the geotechnical report.

Our work has not included verifying that the foundations are excavated to the required dimensions or are located in accordance with the project plans, or observing the placement of reinforcing steel. Prior to pouring the excavations, the building department should check to confirm that all footing excavations are free of water and loose materials.

Additional remarks: CLEAN-UP OF SLOUGH & LOOSE SOIL BEFORE CONCRETE.

We trust this provides the information you require at this time. If you have questions, or wish to discuss this further, please call.

Very truly yours,

**BAUER ASSOCIATES, INC.**

Travis Lopez  
Senior Field Engineer  
707-483-3263

Westside Center  
6470 Mirabel Road  
Post Office Box 460  
Forestville, CA 95436  
707.887.2505

BB (stds)  
Copies Submitted at site: 1