

BLD 18-3996-DF02  
As-Built



Dashboard Hydraulics

# Hydraulics Summary Sheet

## Project Information

WINTERS RESIDENCE  
4558 BRIGHTON DRIVE  
SANTA ROSA, CA.

contract #

Calculation Date: 10/2/2019 10:23 AM

system ID AREA 3 drawing ref FS-2

building  
construction COMBUSTIBLE  
occupancy RESIDENCE  
authority

## Contractor Information

GATEWAY FIRE EQUIPMENT

41 E. 15TH STREET  
MERCED, CA. 95340

calculated by DJJ  
telephone 209-722-9533

fax  
email

## Hydraulics Criteria

density .05 GPM/ft<sup>2</sup>  
remote area 1 HEAD ft<sup>2</sup>  
spr coverage 18' X 18' ft<sup>2</sup>  
sprs flowing 1

system type WET  
design std NFPA 13D, 2016 ED.  
hazard N/A

figure N/A  
curve

## Flow Test


static pressure 61.00 psi  
residual pressure 59.00 psi  
quantity flowing 969.0 GPM

## Sprinklers in Remote

No.	Mfgr	Mod	SIN#	Size	K
1	SENJU	RC-RES	SS8464	1/2"	4.90

REVIEWED FOR  
CODE COMPLIANCE  
OCT 15 2019  
RESILIENCY PERMIT  
CENTER

## Supply / Demand Graph





# Supply Analysis

WINTERS RESIDENCE  
4558 BRIGHTON DRIVE

Source Node	Static Pressure	Residual Pressure	Quantity Flowing	Pressure Available	Total System Flow	Total Pressure Required
Zero	61.00psi	59.00psi	969.0GPM	61.00psi	22.0GPM	37.43psi

Sprinkler Flow:	17.0GPM	Additional Flows:	5.0 GPM
Hose Flow at Zero:	None	Total System Flow:	22.0GPM

Maximum velocity in pipe 3-4 is 9.1 ft/sec

# Nodes Analysis

Node	Elev ft	Device	KFactor	Minimum Flow GPM	Node Pressure psi	Actual Discharge GPM	Notes
8	3.00	Hose Flow			23.54	5.0	
28	10.00	Sprinkler	4.90	17.00	12.04	17.00	



Dashboard Hydraulics

# Pipe Information

WINTERS RESIDENCE  
4558 BRIGHTON DRIVE

From	Elev1 ft	Pipe ID	Flows Added GPM	Diamet er in	Fittings	Length	C Value	Total (Pt)		Notes
To	Elev2 ft	Type	Total			Fitting		psi/ft	Elev (Pe)	
						Total	Frict (Pf)			

27	10.50	1" CPVC		1.1010	E	Len 0.5	C = 150	Pt 28)	12.037		
28	10.00	DR	17.0			Ftg 7.0		0.05037	Pe		-0.217
						Tota 7.5			Pf		0.378
11	10.50	1" CPVC		1.1010	T	Len 3.5	C = 150	Pt 27)	12.198		
27	10.50	BN	17.0			Ftg 5.0		0.05037	Pe		0.000
						Tota 8.5			Pf		0.428

Total Pressure at Node 11) 12.626 psi

9	10.50	1" CPVC		1.1010	3E, 2TR	Len 23.0	C = 150	Pt 10)	13.614		
10	10.50	BN	17.0			Ftg 23.0		0.05037	Pe		0.000
						Tota 46.0			Pf		2.317

Total Pressure at Node 9) 15.931 psi

12	10.50	1" CPVC		1.1010	T,3E, 5TR	Len 66.8	C = 150	Pt 11)	12.626		
11	10.50	BL	4.7			Ftg 31.0		0.00463	Pe		0.000
						Tota 97.8			Pf		0.453
13	10.50	1" CPVC		1.1010	2TR	Len 13.1	C = 150	Pt 12)	13.079		
12	10.50	BL	4.7			Ftg 2.0		0.00463	Pe		0.000
						Tota 15.1			Pf		0.070
14	10.50	1" CPVC		1.1010	2TR	Len 8.0	C = 150	Pt 13)	13.149		
13	10.50	BL	4.7			Ftg 2.0		0.00463	Pe		0.000
						Tota 10.0			Pf		0.046
10	10.50	1" CPVC		1.1010	T,2E, 8TR	Len 63.5	C = 150	Pt 14)	13.195		
14	10.50	BL	4.7			Ftg 27.0		0.00463	Pe		0.000
						Tota 90.5			Pf		0.419

Total Pressure at Node 10) 13.614 psi

10	10.50	1" CPVC		1.1010	T,5TR	Len 25.6	C = 150	Pt 11)	12.626		
11	10.50	BL	12.3			Ftg 10.0		0.02777	Pe		0.000
						Tota 35.6			Pf		0.988

Total Pressure at Node 10) 13.614 psi

8	3.00	1" Type K		0.9950	2E,CV, FS	Len 7.5	C = 150	Pt 9)	15.931	Flow Switch : Loss = 3.00	
9	10.50	FR	17.0			Ftg 9.0		0.08247	Pe		3.250
						Tota 16.5			Pf		1.361
7	1.00	1" Type K	5.0	0.9950	E,GV	Len 2.0	C = 150	Pt 8)	23.542		
8	3.00	FR	22.0			Ftg 3.2		0.13288	Pe		0.867
						Tota 5.2			Pf		0.687

# RECEIVED

OCT 15 2019



Dashboard Hydraulics

## Pipe Information RESILIENCY PERMIT CENTER

WINTERS RESIDENCE  
4558 BRIGHTON DRIVE

From	Elev1 ft	Pipe ID	Flows Added GPM	Diamet er in	Fittings	Length	C Value	Total (Pt)		Notes
						ft		psi	psi	
To	Elev2 ft	Type	Total			Fitting	Friction Loss psi/ft	Elev (Pe)	psi	
						ft		psi		
6	0.00	1.25" SCH. 80 PVC		1.2780	3E	Len 30.0	C = 150	Pt 7)	25.095	
7	1.00	UN	22.0			Ftg 24.0		0.03927	Pe	
				Tota 54.0		Pf	2.121			
5	0.00	1" Type K		0.9950	WDC	Len 1.0	C = 150	Pt 6)	27.649	Double Check Valve Watts 007M1QT: Loss = 3.82
6	0.00	UN	22.0			Ftg 0.0		0.13288	Pe	
				Tota 1.0		Pf	0.133			
4	0.00	1" Type K		0.9950	3E	Len 5.0	C = 150	Pt 5)	31.602	
5	0.00	UN	22.0			Ftg 6.0		0.13288	Pe	
				Tota 11.0		Pf	1.462			
3	0.00	1" Type K		0.9950		Len 18.0	C = 150	Pt 4)	33.063	
4	0.00	UN	22.0			Ftg 0.0		0.13288	Pe	
				Tota 18.0		Pf	2.392			
2	0.00	1½" Type K		1.4810	BWM	Len 1.0	C = 150	Pt 3)	35.455	WATER METER BADGER M120: Loss = 0.56
3	0.00	UN	22.0			Ftg 0.0		0.01915	Pe	
				Tota 1.0		Pf	0.019			
1	0.00	1½" Type K		1.4810		Len 18.0	C = 150	Pt 2)	36.034	
2	0.00	UN	22.0			Ftg 0.0		0.01915	Pe	
				Tota 18.0		Pf	0.345			
0	0.00	1½" Type K		1.4810	T,CS	Len 10.1	C = 150	Pt 1)	36.379	Corporation Stop : Loss = 0.70
1	0.00	UN	22.0			Ftg 8.0		0.01915	Pe	
				Tota 18.1		Pf	0.347			

Total Pressure at Node 0) 37.426 psi