



Hydraulic Overview

BLD18-5684DF01 PC1

Job Number: 19865
Report Description: NFPA13D 2016

Job	
Job Number 19865	Design Engineer Larry Clem
Job Name: HUNLEY RESIDENCE	Phone FAX
Address 1 10 OXFORD COURT	State Certification/License Number C-16 898055
Address 2 SANTA ROSA, CALIFORNIA	AHJ LOCAL FIRE DEPARTMENT
Address 3	Job Site/Building FIRE RESTORATION



System	
Density 0.500gpm/ft ²	Area of Application 392.00ft ²
Most Demanding Sprinkler Data 3.7 K-Factor 10.00 at 7.305	Hose Streams 0.00
Coverage Per Sprinkler 196.00ft ²	Number Of Sprinklers Calculated 2
System Pressure Demand 37.771	System Flow Demand 25.00
Total Demand 25.00 @ 37.771	Pressure Result +32.229 (46.0%)

Supplies					Check Point Gauges				
Node	Name	Flow(gpm)	Hose Flow(gpm)	Static(psi)	Residual(psi)	Identifier	Pressure(psi)	K-Factor(K)	Flow(gpm)
1	Water Supply	980.00		70.000	70.000				

*REVIEWED FOR CODE COMPLIANCE
OCT 23 2019
RESILIENCY PERMIT CENTER*


*THESE ATTACHMENTS ARE PART OF THE APPROVED PLANS
DO NOT REMOVE THEM
OCT 23 2019
PRMD
RESILIENCY PERMIT CENTER
PERMIT # BLD18-5684.DF01*

865Hunley_FP1 Water Supply at Node 1 (980.00, 0.00, 70.000, 70.000)





Water Supply at Node 1



Hydraulic Graph
Water Supply at Node 1

Static Pressure
70.000

Residual Pressure
70.000 @ 980.00

Available Pressure at Time of Test
70.000 @ 25.00

System Demand
37.771 @ 25.00

System Demand (including Hose Allowance at Source)
37.771 @ 25.00



Summary Of Outflowing Devices

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
Hydrant	4	5.00	5.00	0	20.706		
⇒ Sprinkler	101	10.00	10.00	3.7	7.305		
Sprinkler	102	10.00	10.00	3.7	7.305		

⇒ Most Demanding Sprinkler Data



Node Analysis

Job Number: 19865

Report Description: NFPA13D 2016

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
1	-4'-0	S, T(8'-0)	37.771	25.00
4	1'-0	Hyd	20.706	5.00
101	10'-11	Spr(-7.305)	7.305	10.00
102	10'-11	Spr(-7.305)	7.305	10.00
2	-1'-0	E(9'-0)	22.590	
3	-0'-6	cplg(0'-6)	21.610	
5	2'-6	E(7'-0)	15.720	
6	11'-5	E(7'-0)	10.766	
7	11'-5	C(5'-0), Tr(1'-0)	9.897	
8	11'-5	T(5'-0), Tr(1'-0)	7.192	
9	11'-5	T(5'-0)	7.192	

Hydraulic Analysis

Job Number: 19865
Report Description: NFPA13D 2016

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream						Total Length	
Route 1							
DR	1.1010	10.00	3.37	150	0.018874	0'-6"	Pf 0.104
101	10'-11"	10.00	3.7	7.305	Sprinkler,	5'-0"	Pe -0.217
9	11'-5"			7.192	T(5'-0)	5'-6"	Pv
BL	1.1010	9.93	3.35	150	0.018638	100'-1 1/4"	Pf 2.705
9	11'-5"			7.192		45'-0"	Pe
7	11'-5"			9.897	9Tr(1'-0), 3E(7'-0), 3T(5'-0)	145'-1 1/4"	Pv
BL	1.1010	20.00	6.74	150	0.068041	5'-9 1/4"	Pf 0.869
7	11'-5"	10.07		9.897	Flow (q) from Route 2	7'-0"	Pe
6	11'-5"			10.766	E(7'-0)	12'-9 1/4"	Pv
FR	1.1010	20.00	6.74	150	0.068041	8'-11"	Pf 1.084
6	11'-5"			10.766		7'-0"	Pe 3.870
5	2'-6"			15.720	E(7'-0)	15'-11"	Pv
FR	1.0550	20.00	7.34	150	0.083760	2'-6"	Pf 4.340
5	2'-6"			15.720		13'-6"	Pe 0.647
4	1'-0"			20.706	E(2'-0), f(-3.000), Tr(0'-6), sCV(11'-0), Hyd	16'-0"	Pv
FR	1.0550	25.00	9.18	150	0.126567	1'-6"	Pf 0.253
4	1'-0"	5.00		20.706		0'-6"	Pe 0.650
3	-0'-6"			21.610	BalV, cplg(0'-6)	2'-0"	Pv
UG	1.5980	25.00	4.00	150	0.016755	27'-8"	Pf 0.765
3	-0'-6"			21.610		18'-0"	Pe 0.215
2	-1'-0"			22.590	2E(9'-0)	45'-8"	Pv
UG	1.4810	25.00	4.66	150	0.024264	32'-6"	Pf 13.880
2	-1'-0"			22.590		45'-0"	Pe 1.301
1	-4'-0"			37.771	6E(2'-6), BFP(-10.000), WMV(-2.000), AngV(18'-0), LtE(2'-0), BalV(2'-0), S, T(8'-0)	77'-6"	Pv
		0.00			Hose Allowance At Source		
1		25.00					
Route 2							
DR	1.1010	10.00	3.37	150	0.018874	0'-6"	Pf 0.104
102	10'-11"	10.00	3.7	7.305	Sprinkler,	5'-0"	Pe -0.217
8	11'-5"			7.192	T(5'-0)	5'-6"	Pv
BL	1.1010	10.07	3.39	150	0.019112	99'-6 1/2"	Pf 2.705
8	11'-5"	0.07		7.192	Flow (q) from Route 3	42'-0"	Pe
7	11'-5"			9.897	2E(7'-0), 8Tr(1'-0), 3T(5'-0), C(5'-0)	141'-6 1/2"	Pv
Route 3							
BL	1.1010	0.07	0.02	150	0.000002	11'-5"	Pf 0.000
9	11'-5"			7.192		1'-0"	Pe
8	11'-5"			7.192	Tr(1'-0)	12'-5"	Pv

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)		C Value Multiplier				
$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$		Value Of C	100	130	140	150
		Multiplying Factor	0.713	1.16	1.33	1.51




Hydraulic Analysis

Job Number: 19865
Report Description: NFPA13D 2016

Pipe Type	Diameter	Flow	Velocity	HWC		Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	

Pipe Type Legend		Units Legend		Fittings Legend	
AO	Arm-Over	Diameter	Inch	ALV	Alarm Valve
BL	Branch Line	Elevation	Foot	AngV	Angle Valve
CM	Cross Main	Flow	gpm	b	Bushing
DN	Drain	Discharge	gpm	BalV	Ball Valve
DR	Drop	Velocity	fps	BFP	Backflow Preventer
DY	Dynamic	Pressure	psi	BV	Butterfly Valve
FM	Feed Main	Length	Foot	C	Cross Flow Turn 90°
FR	Feed Riser	Friction Loss	psi/Foot	cplg	Coupling
MS	Miscellaneous	HWC	Hazen-Williams Constant	Cr	Cross Run
OR	Outrigger	Pt	Total pressure at a point in a pipe	CV	Check Valve
RN	Riser Nipple	Pn	Normal pressure at a point in a pipe	DelV	Deluge Valve
SP	Sprig	Pf	Pressure loss due to friction between points	DPV	Dry Pipe Valve
ST	Stand Pipe	Pe	Pressure due to elevation difference between indicated points	E	90° Elbow
UG	Underground	Pv	Velocity pressure at a point in a pipe	EE	45° Elbow
				Ee1	11¼° Elbow
				Ee2	22½° Elbow
				f	Flow Device
				fd	Flex Drop
				FDC	Fire Department Connection
				fE	90° FireLock(TM) Elbow
				fEE	45° FireLock(TM) Elbow
				flg	Flange
				FN	Floating Node
				fT	FireLock(TM) Tee
				g	Gauge
				GloV	Globe Valve
				GV	Gate Valve
				Ho	Hose
				Hose	Hose
				HV	Hose Valve
				Hyd	Hydrant
				LtE	Long Turn Elbow
				mecT	Mechanical Tee
				Noz	Nozzle
				P1	Pump In
				P2	Pump Out
				PIV	Post Indicating Valve
				PO	Pipe Outlet
				PRV	Pressure Reducing Valve
				PrV	Pressure Relief Valve
				red	Reducer/Adapter
				S	Supply
				sCV	Swing Check Valve
				Spr	Sprinkler
				St	Strainer
				T	Tee Flow Turn 90°
				Tr	Tee Run
				U	Union
				WirF	Wirsbo
				WMV	Water Meter Valve
				Z	Cap



RECEIVED

OCT 03 2019

RESILIENCY PERMIT CENTER