

PUMP MODEL: _____
 FLOAT MODEL: _____
 TANK MODEL: _____

VCOM-AX20B/PT DRIP Reference Chart

Program: AX20B/PTDRIP System 4.5

Input Functions (Yellow):

- Recirc. RO & Low Level Alarm Float
- Recirc. Override Timer On/Off Float
- Recirc. High Level Alarm Float
- Disc. Timer On/Off Float
- Disc. High Level Alarm/Override Timer
- Recirc. Auxiliary Contact
- Disc. Auxiliary Contact
- Push to Silence

Output Functions (Red):

- Recirc. Pump
- Disc. Pump
- Alarm Light
- Audible Alarm
- Spinfiter Valve
- Drip Flush Valve
- Zone Valve Signal

Conditions for activation:

- Float in up position
- Float in up position
- Float in up position
- Float in up position
- Motor contactor is activated
- Pushbutton is pressed
- Motor contactor is activated

Condition for activation:

- Pump is activated
- Pump is activated
- Alarm Light is activated
- Audible Alarm is activated
- Spinfiter Valve is activated
- Drip Flush Valve is activated
- Zone Valve signal is activated

Test Mode:

The panel should be put in test mode during maintenance activities, troubleshooting, or panel start-up. To enable test mode, hold the silence button on the front of the panel until the audible alarm sounds (about 15 seconds). When testing is complete, the panel can be put back into normal operation by again holding the silence button until the alarm sounds, or the panel will automatically exit test mode after 30 minutes.

Forcing a Call:

To force the panel to call out, push the silence button on the front of the panel 15 times within a one minute period. Allow five minutes for the call to be initiated. Once the panel has made a successful connection, the red "CD" light on the board should be illuminated. The red light remains illuminated until the call has completed.

EIN-CP-REF-91
Rev 1.4 © 03/19/10

SEE INSTALLATION INSTRUCTIONS

Date	Event Counter	Elapsed Time	Me	al	*
10/4/17	4131				
	Annual	Done			
3/27/19	ED 85321				
	Out 296578	In 145072			
10-8-18	DP6572				
	Out 374602	In 203017			
	Annual	Done			
3/4/19	D 7565				
	Out 455119	In 247112			
10/4/19	29705				
	Annual	Done			

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.

VCOM IDENTIFICATION
RTU125627

Controls

VOLTS (Tension) 120 V
MAX AMPS (Ampérage) 5 A
HERTZ (Fréquence) 60 Hz
PHASE 1
ENCLOSURE TYPE RATING 4X
Short circuit current: 5kA rms symmetrical, 240V max

Panel Model: 116m-4x 20 62/PT (0420) 50mm
DOC #: EDU-4x-04-1720 Rev: 2.7

Orencia Systems Inc
www.orencia.com

Motor

RECIRC
VOLTS 240 V
(Tension)
MAX AMPS 16 A
(Ampérage)
H.P. 3 Hp
(Puissance)
HERTZ 60 Hz
(Fréquence)
PHASE 1

Motor

DISCHARGE
VOLTS 240 V
(Tension)
MAX AMPS 16 A
(Ampérage)
H.P. 3 Hp
(Puissance)
HERTZ 60 Hz
(Fréquence)
PHASE 1

UL US LISTED
ENCLOSED INDUSTRIAL CONTROL PANEL
No. CC-734508