

December 18, 2020

Elsa Frick  
11377 Barnett Valley Rd  
Sebastopol CA 95472  
(707) 304-3015  
efrick.consulting@gmail.com

- ☒ 1<sup>st</sup> Review Completed  
☐ 2<sup>nd</sup> Review Completed  
☐ 3<sup>rd</sup> Review Completed

Record Number: SEP20-0541

Septic Site Address: 1384 Barlow Ln Sebastopol

APN: 061-110-044

Subject: SEP20-0541

Dear Elsa Frick,

(Comments by EF in Red in this document)

I have reviewed the above referenced application. Please address all comments noted within this letter then upload a complete resubmittal using Citizen Access portal through Permit Sonoma's website. All cited regulations can be found in the, *Onsite Wastewater Treatment System Regulations and Technical Standards*, Version 7.0 (OWTS Manual). Please provide a transmittal letter that identifies the recipient, sender, project permit number, site address, purpose of submittal, contents included, and date submitted. Please cloud all changes in plans for visibility. Incomplete resubmittals or failure to adequately address all comments will delay the review and permit issuance process.

1. Show the location of the GW's and profile holes used in the compilation method from APN 061-110-025 on the site plan, label that they were used in the compilation GW method, and include the data in the design report.**an exhibit has been added and is un upper right page 1**
2. Label the float controls for the pump and audio/visual alarm to be mounted to a schedule 40 PVC pole inside the pump chamber which will be able to be removed for maintenance. Per OWTS manual 7.0 section 8.5C1**done and noted in clouded area on plan**
3. State that the exposed electrical conduit will be schedule 80 PVC per OWTS manual 7.0 section 8.5D7c.**this is on the plan on the electrical detail, but added to the sump detail as well**
4. Add a bentonite plug in the monitoring well figure. Details can be found in OWTS manual 7.0 Section 11 Figure 11.6**added on monitoring well detail**
5. Show the driveway on the site plan.**it is shown, there is only an il defined dirt drive at this time**

Should you have any questions, please call me at 565-1235 or email me at [Ben.Walker@sonoma-county.org](mailto:Ben.Walker@sonoma-county.org) I work Monday-Friday from 8:00am- 5:00pm.

Sincerely,

Benjamin Walker, EHS  
Environmental Health Specialist Trainee