

The Septic Skeptic, INC
44980 Fish Rock rd
Gualala, CA 95445
(707) 884-5080
www.septicskeptic.com

Site Service Form

Site Location: 22102 Amanita Circle
Timber Cove, CA 95450

Purpose: fall Service 2020 Date: 10-5-20 Time: 11AM

Septic Tank

Solids Inlet: 3x1
Inlet Riser: ok
Inlet Tee: ok

Solids Outlet: 0x0
Outlet Riser: ok
Outlet Tee: filter cleaned

Pump Chamber

Riser: ok Pump: ok Alarm: ok

Control Panel

Dose: 2691 Box: ok electrical: ok

Drain-Field

Odors?: no Saturation?: no Fertility?: no
Down Slope Seepage?: no Ponding?: no
Diversion-Valve?: N/A

Notes: Adjusted floats, Alarm float loose.
All wells dry 1-6
ok

Technician Initials: Anthony