



5880 Commerce Blvd, Suite 105 • Rohnert Park, CA 94928 • (707)578-8185

Standard Pool Calculations

Cardamone-Matthews Residence
2335 Willow Creek Road, Duncan Mills, CA 95450

NOV 18 2019
PERMIT AND RESOURCE
MANAGEMENT DEPARTMENT
BUILDING PLAN CHECK
PERMIT # BD19-4895

Job #	
090048	
Date	
8/1/19	
PE	PM
TP	JMC
1	of 11

DESIGN CRITERIA

CALIFORNIA BUILDING CODE- 2016 EDITION

LATERAL LOADS

Soil EFP: 65 pcf

Water: 62.4 pcf

SOIL CRITERIA

Class 5 soil is assumed with allowable soil bearing pressure of 1500 psf per table 1806.2 in the California Building Code. MKM & Associates has not reviewed site soils conditions and is not responsible for general site stability or soil suitability for the proposed project. A review by a soil engineer or geologist may be desirable by the owner or required by the building official.



Standard Pool Calculations


Resisting Moment of Pool Wall and Radius

Job 090048

Date 8/1/19

PE TP

2 of 11





Standard Pool Calculations

Job #	090048
Date	8/1/19
PE TP	3 of 11

Resisting Moment of Pool Wall and Radius

Spread Sheet Program:

R (ft), radius = Given

D (ft), depth of beginning of radius = Given

h (ft), depth to section (location being analyzed) = Given

t (in), thickness of shotcrete at section = Given

A_p (radians), angle of front of section
 $= \text{if } (h - D > 0) \text{ then } = \arcsin[(h - D)/R] \text{ otherwise } = 0$

A_t (radians), total angle of section
 $= \text{if } (h - D > 0) \text{ then } = A_p(\text{previous}) \text{ otherwise } = 0$

A_s (radians), angle of section
 $= \text{if } (h - D > 0) \text{ then } = A_p - A_t \text{ otherwise } = 0$

x_c (ft), horizontal distance of lead centroid of section
 $= \text{if } (h - D > 0) \text{ then } = (R + t/2)\cos(A_p) \text{ otherwise } = R + t/2$

x_{ms} (ft), moment arm of section
 $= \text{if } (h - D > 0) \text{ then } = (R + t/2)\cos(A_t + 1/2 A_s) - x_c \text{ otherwise } = 0$

L (ft), length of section
 $= \text{if } (h - D > 0) \text{ then } = 2\pi(R + t/2)(A_s/(2\pi)) \text{ otherwise } = h - h(\text{previous})$

Wt_s (lbs), weight of section = Lt (140), (assume unit wt. of gunite & reinf. = 140 pcf)

Wt_{st} (lbs), total weight of previous section = $\sum Wt_s(\text{previous})$

M_{se} (ft-lbs), resisting moment of section $x_{ms}Wt_s$

x_{mc} (ft), horizontal distance from previous section lead centroid to current section lead centroid
 $= \text{if } (h - D > 0) \text{ then } = x_c(\text{previous}) - x_c \text{ otherwise } = 0$

M_t (ft-lbs), total resisting moment of current section = $M_t(\text{previous}) + M_{se} + Wt_{st}x_{mc}$

d_{eff} (in), effective shear depth = $d/\cos(A_t)$

ϕV_c (lbs), shear resistance = $2\sqrt{f'_c}(bd_{eff})(0.75)$

Standard Pool Calculations

Job	090048
Date	8/1/19
PE	TP 4 of 11

Resisting Moment due to Wall and Radius												
Wall Radius (ft.)= 5					Depth to Radius (ft.)= 4.5							
h (ft.)	t (in.)	A _p (rad)	A _t (rad)	A _s (rad)	x _c (ft.)	x _{ms} (ft.)	x _{mc} (ft.)	L (ft.)	Wt _s (lb)	Wt _{st} (lb)	M _{se} (ft-lb)	M _t (ft-lb)
0	9	0.00	0.00	0.00	5.38	0.00	0.00	0.00	0	0	0	0
1	9	0.00	0.00	0.00	5.38	0.00	0.00	1.00	105	0	0	0
2	6	0.00	0.00	0.00	5.25	0.00	0.00	1.00	70	105	0	0
3	6	0.00	0.00	0.00	5.25	0.00	0.00	1.00	70	175	0	0
3.5	6	0.00	0.00	0.00	5.25	0.00	0.00	0.50	35	245	0	0
4	6	0.00	0.00	0.00	5.25	0.00	0.00	0.50	35	280	0	0
4.5	6	0.00	0.00	0.00	5.25	0.00	0.00	0.50	35	315	0	0
5	6	0.10	0.00	0.10	5.22	0.02	0.03	0.53	37	350	1	10
5.5	7	0.20	0.10	0.10	5.18	0.05	0.04	0.54	44	387	2	27
6	7	0.30	0.20	0.10	5.05	0.08	0.14	0.55	45	431	3	89
6.5	8	0.41	0.30	0.11	4.89	0.11	0.16	0.57	53	475	6	171
7	9	0.52	0.41	0.11	4.65	0.14	0.23	0.60	63	528	9	303
7.5	9	0.64	0.52	0.12	4.30	0.19	0.35	0.64	68	592	13	526
8	9	0.78	0.64	0.13	3.84	0.24	0.46	0.71	74	659	18	848
8.5	9	0.93	0.78	0.15	3.23	0.32	0.61	0.82	86	734	27	1325
9	10	1.12	0.93	0.19	2.36	0.46	0.86	1.04	122	819	56	2089
9.5	10	1.57	1.12	0.45	0.00	1.21	2.36	2.44	285	941	345	4656

Wall Design													
EFP (PCF)= 65		f _c = 2.5		ksi		f _y = 60		ksi					
		Soil			Resisting		Design						
h (ft.)	t (in.)	M _s (ft-lb)	V _s (lb)	M _U (ft-lb)	M _t (ft-lb)	M _U (ft-lb)	M _W (ft-lb)	M _U (ft-lb)	d (in.)	A _s (in ² /ft.)	V _U (lb)	d _{eff.} (in)	ΦV _C (lb.)
0	9	0	0	0	0	0	0	0	5.75	0.00	0	5.75	5175
1	9	11	33	17	0	0	11	17	5.75	0.00	52	5.75	5175
2	6	87	130	139	0	0	87	139	2.75	0.02	208	2.75	2475
3	6	293	293	468	0	0	293	468	2.75	0.05	468	2.75	2475
3.5	6	464	398	743	0	0	464	743	2.75	0.08	637	2.75	2475
4	6	693	520	1109	0	0	693	1109	2.75	0.11	832	2.75	2475
4.5	6	987	658	1580	0	0	987	1580	2.75	0.14	1053	2.75	2475
5	6	1354	813	2167	10	12	1344	2155	2.75	0.19	1300	2.75	2475
5.5	7	1802	983	2884	27	32	1775	2851	3.75	0.18	1573	3.77	3392
6	7	2340	1170	3744	89	107	2251	3637	3.75	0.23	1872	3.83	3445
6.5	8	2975	1373	4760	171	205	2804	4555	4.75	0.23	2197	4.98	4481
7	9	3716	1593	5945	303	364	3413	5581	5.75	0.23	2548	6.27	5646
7.5	9	4570	1828	7313	526	631	4045	6682	5.75	0.27	2925	6.64	5976
8	9	5547	2080	8875	848	1017	4699	7857	5.75	0.33	3328	7.19	6469
8.5	9	6653	2348	10645	1325	1590	5328	9055	5.75	0.38	3757	8.05	7246
9	10	7898	2633	12636	2089	2507	5809	10129	6.75	0.36	4212	11.25	10125
9.5	10	9288	2933	14861	4656	5587	4632	9274	6.75	0.32	4693	15.49	13937

Standard Pool Calculations

Job	090048
Date	8/1/19
PE	TP
	5 of 11

Resisting Moment due to Wall and Radius												
Wall Radius (ft.)= 4					Depth to Radius (ft.)= 3.5							
h (ft.)	t (in.)	A _p (rad)	A _t (rad)	A _s (rad)	x _c (ft.)	x _{ms} (ft.)	x _{mc} (ft.)	L (ft.)	Wt _s (lb)	Wt _{st} (lb)	M _{se} (ft-lb)	M _t (ft-lb)
0	9	0.00	0.00	0.00	4.38	0.00	0.00	0.00	0	0	0	0
1	9	0.00	0.00	0.00	4.38	0.00	0.00	1.00	105	0	0	0
2	6	0.00	0.00	0.00	4.25	0.00	0.00	1.00	70	105	0	0
3	6	0.00	0.00	0.00	4.25	0.00	0.00	1.00	70	175	0	0
3.5	6	0.00	0.00	0.00	4.25	0.00	0.00	0.50	35	245	0	0
4	6	0.13	0.00	0.13	4.22	0.02	0.03	0.53	37	280	1	10
4.5	6	0.25	0.13	0.13	4.12	0.06	0.10	0.54	38	317	2	45
5	6	0.38	0.25	0.13	3.94	0.10	0.18	0.56	39	355	4	111
5.5	7	0.52	0.38	0.14	3.72	0.14	0.22	0.60	49	394	7	206
6	7	0.68	0.52	0.15	3.35	0.19	0.37	0.65	53	443	10	378
6.5	8	0.85	0.68	0.17	2.87	0.27	0.48	0.75	70	496	19	637
7	8	1.07	0.85	0.22	2.10	0.40	0.77	0.94	88	566	35	1107
7.5	8	1.57	1.07	0.51	0.00	1.08	2.10	2.19	204	654	221	2701

Wall Design													
EFP (PCF)= 65		f _c = 2.5		ksi		f _y = 60		ksi					
		Soil			Resisting		Design						
h (ft.)	t (in.)	M _s (ft-lb)	V _s (lb)	M _U (ft-lb)	M _t (ft-lb)	M _U (ft-lb)	M _W (ft-lb)	M _U (ft-lb)	d (in.)	A _s (in ² /ft.)	V _U (lb)	d _{eff.} (in)	ΦV _c (lb.)
0	9	0	0	0	0	0	0	0	5.75	0.00	0	5.75	5175
1	9	11	33	17	0	0	11	17	5.75	0.00	52	5.75	5175
2	6	87	130	139	0	0	87	139	2.75	0.02	208	2.75	2475
3	6	293	293	468	0	0	293	468	2.75	0.05	468	2.75	2475
3.5	6	464	398	743	0	0	464	743	2.75	0.08	637	2.75	2475
4	6	693	520	1109	10	12	683	1097	2.75	0.11	832	2.75	2475
4.5	6	987	658	1580	45	54	942	1526	2.75	0.13	1053	2.77	2495
5	6	1354	813	2167	111	133	1243	2034	2.75	0.18	1300	2.84	2556
5.5	7	1802	983	2884	206	247	1597	2637	3.75	0.16	1573	4.05	3641
6	8	2340	1170	3744	378	454	1962	3290	4.75	0.19	1872	5.48	4936
6.5	8	2975	1373	4760	637	765	2338	3995	4.75	0.20	2197	6.08	5476
7	8	3716	1593	5945	1107	1329	2608	4616	4.75	0.23	2548	7.18	6463
7.5	8	4570	1828	7313	2701	3241	1869	4071	4.75	0.20	2925	9.81	8830


Standard Pool Calculations

Job	090048
Date	8/1/19
PE	TP
	6 of 11

Resisting Moment due to Wall and Radius												
Wall Radius (ft.)= 1				Depth to Radius (ft.)= 3								
h (ft.)	t (in.)	A _p (rad)	A _t (rad)	A _s (rad)	x _c (ft.)	x _{ms} (ft.)	x _{mc} (ft.)	L (ft.)	Wt _s (lb)	Wt _{st} (lb)	M _{se} (ft-lb)	M _t (ft-lb)
0	9	0.00	0.00	0.00	1.38	0.00	0.00	0.00	0	0	0	0
1	9	0.00	0.00	0.00	1.38	0.00	0.00	1.00	105	0	0	0
2	6	0.00	0.00	0.00	1.25	0.00	0.00	1.00	70	105	0	0
3	6	0.00	0.00	0.00	1.25	0.00	0.00	1.00	70	175	0	0
3.5	6	0.52	0.00	0.52	1.08	0.12	0.17	0.65	46	245	6	47
4	6	1.57	0.52	1.05	0.00	0.63	1.08	1.31	92	291	57	419

Wall Design													
EFP (PCF)= 65		f'_c = 2.5		ksi		f_y = 60		ksi					
		Soil			Resisting		Design						
h (ft.)	t (in.)	M_s (ft-lb)	V_s (lb)	M_U (ft-lb)	M_t (ft-lb)	M_U (ft-lb)	M_w (ft-lb)	M_U (ft-lb)	d (in.)	A_s (in ² /ft.)	V_U (lb)	$d_{eff.}$ (in)	ΦV_C (lb.)
0	9	0	0	0	0	0	0	0	5.75	0.00	0	5.75	5175
1	9	11	33	17	0	0	11	17	5.75	0.00	52	5.75	5175
2	6	87	130	139	0	0	87	139	2.75	0.02	208	2.75	2475
3	6	293	293	468	0	0	293	468	2.75	0.05	468	2.75	2475
3.5	6	464	398	743	47	56	418	687	2.75	0.08	637	2.75	2475
4	6	693	520	1109	419	503	274	607	2.75	0.07	832	3.18	2858

CHECK SOIL BEARING PRESSURE AT FILLED CONDITION ;
(INADEQUATE SOIL SUPPORT)



$$P_w = \frac{62.4 \text{ pcf} (H^2)}{2}$$

$$M_{wT} = \frac{62.4 (H^3)}{6}$$

$$W_s = 62.4 (H) + \left(\frac{t_s}{12}\right) (140)$$

$$P_s = EFP \left(\frac{n+H}{2}\right) (H-n)$$

$$P_s = \frac{n+H}{2} (H-n) EFP$$

$$\bar{Y}_{Ps} = \frac{(H-n)(2n+H)}{3(H+n)}$$

$$M_{OT} = \frac{62.4 (H^3)}{6}$$

$$M_{RES} = \left(62.4 (H) + \left(\frac{t_s}{12}\right) 140\right) \left(\frac{L^2}{2}\right) + \frac{(H-n)^2 EFP (2n+H)}{6}$$

$H = 7.5'$ $t_s = 9''$ $L = 7'$:

$$M_{OT} = \frac{62.4 (7.5')^3}{6} = 4388' \#$$


$$M_{RES} = \left(62.4 (7.5) + \left(\frac{9}{12}\right) 140\right) \left(\frac{7^2}{2}\right) + \frac{(7.5-5)^2 55 (2(5)+7.5)}{6} = 1504' \#$$

$$M_{NET} = 1504 - 4388 = 10653$$

$$\Sigma V = \left[62.4 (7.5) + \left(\frac{9}{12}\right) 140\right] 7 = 4011 \#$$

$$e = \frac{10653}{4011} = 2.656'$$

$$e = \frac{1}{2} = 2.656 = 0.044$$



$$e = 3.5 - 2.656 = 0.844'$$

$$\frac{P}{A} \pm \frac{Mc}{I}$$

$$c = 3.5' \quad I = \frac{1}{12}(1')(7')^3 = 28.6 \text{ ft}^4$$

$$M = 0.844(4011) = 3385 \text{ ft-lb}$$

$$P = 4011 \text{ lb}$$

$$A = 7 \text{ ft}^2$$

$$P/A = 573 \text{ PSF}$$

$$\frac{Mc}{I} = \frac{3385(3.5)}{28.6 \text{ ft}^4} = 415 \text{ PSF}$$

$$f_{\max} = 988 \text{ PSF} \quad f_{\min} = 158 < 1000 \text{ PSF} \quad \underline{\text{OK}}$$

$$H = 5.5' \quad t_f = 9'' \quad L = 4.5'$$

$$M_{OT} = 1730 \text{ ft-lb}$$

$$M_{RES} = (624(5.5) + \frac{9}{12}(140)) \frac{4.5^2}{2} = 4530 \text{ ft-lb}$$

$$M_{NET} = 2807 \quad \Sigma V = 624(5.5) + \frac{9}{12}(140)(4.5) = 2017 \text{ lb}$$

$$a = \frac{2807}{2017} = 1.39' \quad e = \frac{4.5}{2} - 1.39 = 0.858'$$

$$f_{\max} = \frac{2(2017)}{3(1.39)} = 967 \text{ PSF} < 1000 \text{ PSF} \quad \underline{\text{OK}}$$

$$H = 4' 0'' \quad t_s = 9'' \quad L = 3$$

$$M_{OT} = 666 \text{ ft}$$

$$M_{RES} = \left[(62.4 \times 4) + \frac{9}{12} (140) \right] \cdot 3 \cdot \frac{2}{2} = 1596 \text{ ft} \quad \Sigma U = 1064 \text{ ft}$$

$$M_{NET} = 930$$

$$a = \frac{930}{1064} = 0.874$$

$$f_{max} = \frac{2(1064)}{3(0.874)} = 811 \text{ PSF} < 1000 \text{ OK}$$

Standard Pool Calculations

Job	090048	
Date	8/1/19	
PE	TP	10 of 11

Wall Design for Water Pressure With Inadequate Soil Support													
EFP (PCF)= 62.4		f'_c = 2.5		ksi		f_y = 60		ksi		Neglect upper 5' of soil			
		Water			Resisting		Design						
h (ft.)	t (in.)	M_s (ft-lb)	V_s (lb)	M_U (ft-lb)	M_t (ft-lb)	M_U (ft-lb)	M_w (ft-lb)	M_U (ft-lb)	d (in.)	A_s (in ² /ft.)	V_U (lb)	$d_{eff.}$ (in)	ϕV_C (lb.)
0	9	0	0	0	0	0	0	0	3.75	0.00	0	3.75	3375
1	9	10	31	17	0	0	10	17	3.75	0.00	49.92	3.75	3375
2	7	83	125	133	0	0	83	133	3.75	0.01	199.7	3.75	3375
3	7	281	281	449	0	0	281	449	3.75	0.04	449.3	3.75	3375
3.5	7	446	382	713	0	0	446	713	3.75	0.06	611.5	3.75	3375
4	7	666	499	1065	0	0	666	1065	3.75	0.09	798.7	3.75	3375
4.5	7	948	632	1516	0	0	948	1516	3.75	0.12	1011	3.75	3375
5	7	1300	780	2080	0	0	1300	2080	3.75	0.15	1248	3.75	3375



PE	TP	/// of ///
----	----	------------

441 College Avenue - Santa Rosa, CA 95401 - (707) 578-8185 - Fax (707)