

State of California
Well Completion Report
 Form DWR 188 In Review 3/4/2024
 WCR2022-013365

Owner's Well Number _____ Date Work Began 11/02/2022 Date Work Ended 11/02/2022
 Local Permit Agency Sonoma County Permit & Resource Management Department
 Secondary Permit Agency _____ Permit Number WEL22-0394 Permit Date 10/12/2022

Well Owner (must remain confidential pursuant to Water Code 13752)	Former Use
Name <u>STONY POINT FLATS,</u>	Activity <u>Destroy</u>
Mailing Address <u>30 Meyers Court</u>	Former Use <u>Water Supply</u>
<u>C/O Michelle Olson</u>	
City <u>Novato</u> State <u>CA</u> Zip <u>94947</u>	

Well Location	
Address <u>2268 Stony Point RD</u>	APN <u>125-521-008</u>
City <u>Santa Rosa</u> Zip <u>95407</u> County <u>Sonoma</u>	Township <u>07 N</u>
Latitude <u>38 24 56.0699 N</u> Longitude <u>-122 44 19.6332 W</u>	Range <u>08 W</u>
Deg. Min. Sec. Deg. Min. Sec.	Section <u>34</u>
Dec. Lat. <u>38.415575</u> Dec. Long. <u>-122.738787</u>	Baseline Meridian <u>Mount Diablo</u>
Vertical Datum _____ Horizontal Datum <u>WGS84</u>	Ground Surface Elevation _____
Location Accuracy _____ Location Determination Method _____	Elevation Accuracy _____
	Elevation Determination Method _____

Borehole Information	
Orientation <u>Vertical</u> Specify _____	
Drilling Method _____ Drilling Fluid _____	
Total Depth of Boring _____ Feet	
Total Depth of Completed Well _____ Feet	

Water Level and Yield of Completed Well	
Depth to first water _____ (Feet below surface)	
Depth to Static _____	
Water Level _____ (Feet) Date Measured _____	
Estimated Yield* _____ (GPM) Test Type _____	
Test Length _____ (Hours) Total Drawdown _____ (feet)	
*May not be representative of a well's long term yield.	

Destruction Details:
 Abandoned 5" x 6' steel cased well per Sonoma County requirements. Perforate casing at 5', Tailgate cement from bottom to 3' bg. Over-excavate and cut casing and mushroom cap.

Other Observations:

State of California
Well Completion Report
 Form DWR 188 Submitted 11/14/2022
 WCR2022-013366

Owner's Well Number _____ Date Work Began 11/02/2022 Date Work Ended 11/02/2022
 Local Permit Agency Sonoma County Permit & Resource Management Department
 Secondary Permit Agency _____ Permit Number WEL22-0394 Permit Date 10/12/2022

Well Owner (must remain confidential pursuant to Water Code 13752)	Former Use
Name <u>STONY POINT FLATS,</u>	Activity <u>Destroy</u>
Mailing Address <u>30 Meyers Court</u>	Former Use <u>Water Supply</u>
<u>C/O Michelle Olson</u>	
City <u>Novato</u> State <u>CA</u> Zip <u>94947</u>	

Well Location	
Address <u>2268 Stony point RD</u>	APN <u>125-521-008</u>
City <u>Santa Rosa</u> Zip <u>95407</u> County <u>Sonoma</u>	Township <u>07 N</u>
Latitude <u>38</u> <u>24</u> <u>56.0051</u> N Longitude <u>-122</u> <u>44</u> <u>20.346</u> W	Range <u>08 W</u>
Deg. Min. Sec. Deg. Min. Sec.	Section <u>34</u>
Dec. Lat. <u>38.415557</u> Dec. Long. <u>-122.738985</u>	Baseline Meridian <u>Mount Diablo</u>
Vertical Datum _____ Horizontal Datum <u>WGS84</u>	Ground Surface Elevation _____
Location Accuracy _____ Location Determination Method _____	Elevation Accuracy _____
	Elevation Determination Method _____

Borehole Information	
Orientation <u>Vertical</u> Specify _____	
Drilling Method _____ Drilling Fluid _____	
Total Depth of Boring _____ Feet	
Total Depth of Completed Well _____ Feet	

Water Level and Yield of Completed Well	
Depth to first water _____ (Feet below surface)	
Depth to Static _____	
Water Level _____ (Feet) Date Measured _____	
Estimated Yield* _____ (GPM) Test Type _____	
Test Length _____ (Hours) Total Drawdown _____ (feet)	
*May not be representative of a well's long term yield.	

Destruction Details:
 Abandoned 8" x 60' steel cased well per Sonoma County requirements.
 Perforated casing from 30' to 5' below grade. Tremie cement grout from bottom 5' below grade. Over-excavate and cut casing and mushroom cap. Backfill to grade with native soils.

Other Observations:

2268 Stony Point Road

Santa Rosa, Ca. 95407

APN #125-521-008

APPROVED
PERMIT SONOMA
WELL AND SEPTIC SECTION
APPROVED BY: Chris Liu
DATE: October 12, 2022
PERMIT #: WEL22-0394



5" Well
8" Well

Weeks Drilling & Pump Company
P.O. Box 176
Sebastopol, Ca. 95473

GPS:
5" Well 38.415575° / -122.738787°
8" Well 38.415557° / -122.738985°

Legend
Feature 1

400 ft
N