

Apex Septic Design, Inc.

P.O. Box 11247
Santa Rosa, CA 95406

(707) 322-5827
apexsepticdesign@gmail.com



March 21, 2024

Well And Septic Section
Sonoma County PRMD
2550 Ventura Avenue
Santa Rosa, CA 95403

Re: Wet weather groundwater determination at 5975 Petersen Road in Sebastopol, CA 95472
APN: 024-010-014 Permit #: WSR24-0031

Dear Septic Staff:

A wet weather groundwater determination was conducted at the subject parcel on March 21, 2024. The measurements show the distances from the existing ground surface to either the surface of the groundwater or bottom of the groundwater holes.

Wet weather groundwater holes:

GW 1: Water at 32.125" depth

GW 2: Water at 31.75" depth

GW 3: Water at 30.375" depth

GW 4: Water at 27.75" depth

For further information or questions I can be reached at (707) 322-5827.

Respectfully,

A handwritten signature in black ink that reads "Tai Nguyen" followed by a long horizontal flourish.

Tai Nguyen
Registered Environmental Health Specialist #7177





Record Number: WSR24-0031

Septic Site Address: 5975 Petersen Rd, Sebastopol, CA 95472


Inspector: Leah Redon

Date: 03/21/2024

Fraction Conversion		
1/8 inch= 0.125	1/2 inch =0.500	7/8 inch= 0.875
1/4 inch=0.250	5/8 inch=0.625	
3/8 inch =0.375	3/4 inch = 0.750	

Limiting Condition is the measurement to the ground water. If it is a dry hole, limiting condition is the bottom of the hole.

Ground Water Test Readings					
GW Hole #	Measurement from Top of the Pipe to Limiting conditions	Top of pipe to ground (surface)	Depth to GW	WET or DRY	Remarks
1	53.875	22.75	31.125	Wet	
2	54.875	22.625	32.25	Wet	
3	58.75	26.75	32	Wet	
4	54.75	29	25.75	Wet	
				N/A	
				N/A	
				N/A	
				N/A	
				N/A	
				N/A	



***If there is no pipe, measure from the ground surface to limiting conditions.