

# Duncan Engineering Inc.

PO Box 1348, Mendocino, CA 95460  
Ph (707) 964-9604  
Fax (707) 964-0998

Job No. 18-177

December 18, 2019

Sonoma County Building Department  
Via email to contractor

## TRUSS CALCULATION REVIEW

Project: Fish Residence  
173 Wembley Court  
Santa Rosa, CA

I have reviewed the truss layouts and calculations by American Truss (Stamped by xxx on xxx, for trusses G1-M2a) for the above noted project and find them acceptable and in compliance with the plans. The designs are acceptable for the transfer of all vertical and lateral loads required by the structural calculations. A copy of the layout is attached for reference.

Note that this is a change from the original stick framed roof.

Please note that the calculations and layout were only reviewed for their overall conformance to the original design intent. The actual truss design is the responsibility of the truss manufacture. Also, measurement and spacing is the responsibility of the contractor to verify and where not checked except in a general sense to confirm loadings. Lastly, it is important for the builder to read, understand and implement the installation instructions that come with the trusses, these include both temporary and permanent bracing.

Please call if there are any questions.

Sincerely,  
David Duncan



1/2