

MEMO LETTER

3208-4846


CSE FILE #: 20-2

PROJECT NAME: CHANDLER RESIDENCE

PROJECT ADDRESS: 24 BRIGHTON COURT, SANTA ROSA, CA 95403

DEAR JOEL,

AT GRIDLINE E, THE FOOTING MAY BE OMITTED, BUT A SQUARE PAD NEEDS TO BE PLACED UNDER THE HOLDDOWNS AS NOTED BELOW:



SINCERELY,

CHRISTIAN HOLBROOK,
PRINCIPAL STRUCTURAL ENGINEER



OCTOBER 22, 2020

From: cseholbrook@gmail.com
Subject: Chandler Residence - CSE Memo Letter for Missing Footing
Date: Oct 22, 2020 at 9:19:36 AM
To: chandlerconst@hotmail.com

Good morning,

Please find below the Dropbox link to the requested memo letter for the above referenced project. Once selected, the link will automatically download the file(s) to your device. If using Windows, the file(s) will automatically download to the "Downloads" directory.


When printing these PDF files, please use the **latest version of Adobe Acrobat** to ensure a clean print. Do not print the PDF directly from Dropbox.

Please let me know if you have any questions or need anything else.

CSE Memo Letter

Thanks again,

Christian Holbrook, S.E. 5250
Principal Structural Engineer



1635 Tahoe Drive,
Santa Rosa, CA 95405
707.637.3241 Office/Cell
530.219.4389 Cell
cseholbrook@gmail.com